GULF STATES UTILITIES COMPANY

RIVER BEND STATION POST OFFICE BOX 220 ST. FRANCISVILLE, LOUISIANA 70775

AREA CODE 504 635-6094 346-8651

May 17, 1985
RBG- 21027
File Nos. G9.5, G9.25.1.1

Mr. Robert D. Martin, Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

RECEIVED
MAY 28 1985

Dear Mr. Martin:

River Bend Station - Unit 1
Docket No. 50-458
Final Report/DR-156

Gulf States Utilities Company (GSU) has completed its evaluation of DR-156 concerning non-essential devices supplied by General Electric Company (e.g., conductivity cells, conductivity indicators, etc.) that are connected to Class 1E busses. Analysis of the devices concluded that there were no non-essential devices connected to Class 1E busses which could adversely affect the safe operations f the plant. GSU has therefore determined this condition is not reportable under 10CFR50.55(e). However, Field Deviation Disposition Request No. LD1-2030 was issued to transfer G33-N008 power to the Reactor Protection System.

Sincerely,

J. E. Booker

J. E. Booker
Manager-Engineering,
Nuclear Fuels & Licensing
River Bend Nuclear Group

PJD
JEB/PJD/amg

cc: Director of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

NRC Resident Inspector-Site

85-375

8506060542 850517
PDR ADOCK 05000458
S PDR

IE27
1/0