

MAR 7 1985

NOTE TO: G. Millman
MSEB, DET, NRR

FROM: Eric Jakel, OELD *EE Jakel*

SUBJECT: PROPOSED RULE TO AMEND 10 CFR 50.55a

I have reviewed the Staff Paper containing the proposed rule to amend § 50.55a of 10 CFR Part 50. I have clipped the margins in four places where minor editorial changes are needed or where typographical errors appear.

I have no legal objection to the substance of the paper, but I do think that the format on pages 8 and 9 of the Federal Register notice is in error. Attached to this note is a corrected redraft of that portion of the Federal Register notice that I believe to be in error. I will be quite willing to accept whatever DRR (Joe Felton and John Philips) approves.

Enclosure:
As stated

§ 50.55a Codes and standards.

* * * * *

(b) * * *

(1) As used in this section, references to Section III of the ASME Boiler and Pressure Vessel Code refer to Section III, Division 1, and include editions through the 1983 Edition and Addenda through the Summer 1984 Addenda.

(2) As used in this section, references to Section XI of the ASME Boiler and Pressure Vessel Code refer to Section XI, Division 1, and include editions through the 1983 Edition and Addenda through the Summer 1983 Addenda, subject to the following limitations and modifications:

* * * * *

(g) Inservice inspection requirements:

* * * * *

(3) For a boiling or pressurized water-cooled nuclear power facility whose construction permit was issued on or after July 1, 1974:

(i) Components which are classified as ASME Code Class 1 shall be designed and be provided with access to enable the performance of inservice examination of such components and shall meet the preservice examination requirements set forth in Section XI of editions of the ASME Boiler and Pressure Vessel Code and Addenda⁶ applied to the construction of the particular component.

(ii) * * *

(iii) Pumps and valves which are classified as ASME Code Class 1 shall be designed and be provided with access to enable the performance of inservice testing of the pumps and valves for assessing operational readiness set forth in Section XI of editions of the ASME Boiler and Pressure Vessel Code and Addenda⁶ applied to the construction of the particular pump or valve or the Summer 1973 Addenda, whichever is later.

* * * * *

(4) * * *

(i) * * *

(ii) * * *

(iii) [Reserved]

* * * * *