




GULF STATES UTILITIES COMPANY

RIVER BEND STATION POST OFFICE BOX 220 ST. FRANCISVILLE, LOUISIANA 70775
AREA CODE 504 635-6094 346-8651



May 16, 1985
RBG- 21020
File Nos. G9.5, G9.25.1.1

Mr. Robert D. Martin, Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Dear Mr. Martin:

River Bend Station - Unit 1
Docket No. 50-458
Final Report/DR-285

Gulf States Utilities Company (GSU) has completed its evaluation of DR-285 concerning new instrument setpoints for Rosemount 1152 devices resulting from a revised instrument setpoint methodology. The condition resulted from a controlled review to establish a new design basis. Since the condition does not represent a deficiency in final design, GSU has determined this condition does not meet the reporting requirements of 10CFR50.55(e).

Sincerely,

J. E. Booker

J. E. Booker
Manager-Engineering,
Nuclear Fuels & Licensing
River Bend Nuclear Group

^{PJD}
JEB/PJD/amg

cc: Director of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

NRC Resident Inspector-Site

85367
8506060703 850516
PDR ADOCK 05000458
S PDR

15-27
1/0