



85 JAN 22 P 2: 03

**Florida
Power**
CORPORATION

January 18, 1985
3F0185-06

Mr. J. P. O'Reilly
Regional Administrator, Region II
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, GA 30323

Subject: Crystal River Unit 3
Docket No. 50-302
Operating License No. DPR-72
I.E. Inspection Report No. 84-14
Supplemental Response

Dear Sir:

On June 29, 1984, Florida Power Corporation (FPC) responded to the subject Inspection Report (3F0684-17). In the Corrective Action, FPC committed to install by October 31, 1984, an enhanced program that will be available in the Control Room which will more fully meet the requirements of IWP 6210 and IWV 6210. On November 1, 1984, FPC amended this date to November 30, 1984, due to software developmental and hardware problems (3F1184-03). The computer program was developed by November 30, 1984. Use and implementation of the program has not produced the desired results, therefore, FPC proposes to manually implement the program by listing Inservice Inspection Pump and Valve data. This data will be used to meet the IWP 6210 and IWV 6210 criteria. All data will be available on site. This effort will be completed by February 28, 1985.

In addition to the required ASME Section XI data taken at Crystal River Unit 3, FPC has other more stringent administrative program requirements. The monitoring of these parameters provides additional assurance of proper equipment performance.

Sincerely,

G.R. Westafer
Manager, Nuclear Operations
Licensing and Fuel Management

DG: jel

cc: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

8507170375 850118
PDR ADOCK 05000302
Q PDR

110

IEO1