

VEGP PLANT REVIEW BOARD MEETING MINUTES

MEETING NO. 90-57 DATE 04/12/90 PAGE 1 OF 4
 MEETING CONVENED 1:10 AM/PM; MEETING ADJOURNED 2:50 AM/PM
 (* VIA TELECON) _____

THIS MEETING CHAIRED BY:

(x) CHAIRMAN () VICE CHAIRMAN W. F. Kitchens

VOTING MEMBERS PRESENT: M. W. Horton J. G. Aufdenkampe
J. E. Swartzwelder A. L. Mosbaugh
 PRB SECRETARY C. Cross Tynan

NON-VOTING MEMBERS PRESENT: G. R. Frederick M. B. Lackey
K. R. Holmes C. P. Stinespring

VOTING ALTERNATES PRESENT:

<u>M. L. Hobbs</u>	FOR	<u>H. M. Handfinger</u>
<u>I. A. Kochery</u>	FOR	<u>R. L. LeGrand</u>

NON-VOTING ALTERNATES PRESENT:

_____	FOR	_____
_____	FOR	_____
_____	FOR	_____
_____	FOR	_____
_____	FOR	_____

GUESTS/TECHNICAL ADVISORS:

W. K. Smith

T. E. Webb

PRB ACTION ITEMS OPENED: None

PRB ACTION ITEMS CLOSED: None

PRB MINUTES APPROVED : 90-48 to and including 90-56

C. Cross Tynan

PRB SECRETARY

W F Kitchens

PRB CHAIRMAN

CC: NRC RESIDENT INSPECTOR

(FORM NAME=PRBAGEND)

9610040171 960827
 PDR FOIA
 WILMOTH95-81 PDR

PRB MEETING MINUTES CONTINUATION SHEET

- A. Meeting Minutes 90-48, 90-49, 90-51, 90-52, 90-53, 90-54 and 90-55 were unanimously approved as presented.

Meeting Minutes 90-50 were unanimously approved with comment to indicate that the attached Event Critique Package is a draft report.

Meeting Minutes 90-56 were unanimously approved as presented, however J. E. Swartzwelder stated that a revision to Procedure 12005-C was no longer needed as determined from the review since the last PRB meeting.

- B. The following items were unanimously recommended for approval. No unreviewed safety question involved.

12006-C, Rev. 16 "Unit Cooldown to Cold Shutdown"

TCP-T-ENG-90-09-02 "Diesel Generator Functional Checkout"

TCP-T-ENG-90-13-01 "Sequencer Operability Check"

TCP-T-ENG-90-11-01 "A-Train Undervoltage Test"

Quarterly Operational Monitoring Report (NOTS-00352)

LDCR FS 90-11 Revise FSAR Table 9.5.1-10, Section 9.5.1.2.1.4.B and 9A.1.86.N - DCP 88V1N0046 adds two sprinkler heads to Control Building Room 178 by extending branch piping from system 079.

LDCR FS 89-087 Revise FSAR Table 7.5.2-1 to make ERF indication of variables (Feedwater Bypass Isolation Valve Status) consistent with actual valve function. Also to clarify other indications for Reg. Guide 1.97 conformance (DCP 89-V2N0320).

LDCR TS 90-05 Change to Tech. Spec. 4.0.3 and associated bases - Revise in accordance with Generic Letter 87-09 to include a specific acceptable time limit of 24 hours to complete an inadvertently missed surveillance before the provisions of the Action Requirements apply.

93100-C, Rev. 6	"Refueling Tools and Equipment Preservice Inspection and Checkout"
83503-1, Rev. 0	"Unit Operation During Secondary Plant Performance Test"
83504-1, Rev. 0	"Secondary Plant Performance Test Instrumentation Installation and Setup"

Settlement Monitoring Report to NRC (Correspondence ELV-01473)

- C. The following items were unanimously recommended for approval with comment. No unreviewed safety question involved.

19033-C, Rev. 6	"ES-3.3 Post-SGTR Cooldown Using Steam Dump". Reword the Caution on page 2, add (initiate an offsite release permit).
-----------------	--

19100-C, Rev. 5	"ECA-0.0 Loss of All AC Power". Page 5, underline RAT. Step 3F, sample valve should be repeated elsewhere in procedure.
-----------------	--

LER 1-90-008	"Typographical Error Leads to a Missed ASME Section XI Valve Test". Change title to "procedural inadequacy" instead of "typographical error". Section D - delete last sentence.
--------------	--

- D. The following items were tabled by the board with the comment indicated.

00409-C, Rev. 7	"Open Item/Commitment Tracking". Review to determine if the proposed change is necessary.
-----------------	---

LER 1-90-06	"Loss of Offsite Power Leads to Site Area Emergency". Section A - delete items a) and b) and include another section that would state this is a summary of Site Area Emergency event. Return/rewrite as 8 pages or less.
-------------	--

E. The board unanimously concurred with the reportability determination for the following Deficiency Cards.

1-90-0157	1-90-0182
1-90-0165	1-90-0183
1-90-0166	1-90-0185
1-90-0167	1-90-0186
1-90-0168	1-90-0192
1-90-0171	1-90-0194
1-90-0173	1-90-0196
1-90-0175	1-90-0193
1-90-0177	1-90-0197
1-90-0179	1-90-0189
1-90-0180	1-90-0200

Meeting Adjourned