



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39215-1640

85 APR 9 P 1:34
April 3, 1985

NUCLEAR LICENSING & SAFETY DEPARTMENT

U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N. W., Suite 2900
Atlanta, Georgia 30323

Attention: Dr. J. Nelson Grace, Regional Administrator

Dear Dr. Grace:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-29
File: 0260/L-835.0
Special Report 85-002/1,
Inoperability of Post Accident
Radiation Monitors
AECM-85/0107

Reference: AECM-85/0092, March 18, 1985

On March 20, 1985, Mississippi Power & Light Company (MP&L) notified Vince Panciera of your office that the expected installation date of environmentally qualified conduit provided in Special Report 85-002/0 (Referenced letter) had been revised to March 22, 1985. The purpose of this follow-up is to document that telephone conversation and to provide the actual completion date of the installation of environmentally qualified conduit for the Containment and Drywell post accident radiation monitors. The monitors were restored on March 26, 1985. The plant was in Cold Shutdown during the period the monitors were inoperable.

Yours truly,

L. F. Dale
Director

EBS/SHH:rw

cc: (See Next Page)

8506070078 850403
PDR ADDCK 05000416
S PDR

Official Copy
IE22
1/0

cc: Mr. J. B. Richard
Mr. O. D. Kingsley, Jr.
Mr. R. B. McGehee
Mr. N. S. Reynolds
Mr. G. B. Taylor

Mr. James M. Taylor, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555