

JUL 05 1985

Docket No.: 50-440

Mr. Murray R. Edelman, Vice President
Nuclear Operating Group
The Cleveland Electric Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Dear Mr. Edelman:

Subject: Acceptability of the Perry Nuclear Power Plant (Unit 1)
Initial Test Program as Amended Through FSAR Amendment 17

The NRC staff has completed its review of the Perry Unit 1 Initial Test Program changes and clarifications documented in FSAR Amendments 7 thru 17, which include responses to staff questions provided by your letters dated April 19 and April 29, 1985. On the basis of that review, the staff finds the Initial Test Program, as amended thru FSAR Amendment 17, acceptable.

In FSAR Amendment 17, exception was proposed in the performance of the 2-hour test of the TDI diesel generators at 110% of rated load, as specified in Section C.2.a(3) of Regulatory Guide 1.108. As a part of its acceptance of the amended Initial Test Program for Perry Unit 1, this proposed exception is granted.

These acceptances are reflected in the enclosed supplemental safety evaluation which we propose to incorporate in the next Perry SER supplement.

Sincerely,

ORIGINAL SIGNED BY:

B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

Enclosure: As stated

cc: See next page

DISTRIBUTION:

Docket File

NRC PDR

Local PDR

PRC System

NSIC

LB#1 R/F

MRushbrook

JStefano

OELD

ACRS (16)

JPartlow

BGrimes

EJordan

LB#1/DL

JStefano/mac

07/5/85

DBeckham, DHFS

DZiemann, PSRB/DHFS

RBecker, PSRB/DHFS

MSrinivasan, PSB/DSI

AUngono, PSB/DSI

CBerlinger, TDI Task Group

LB#1/DL
BJYoungblood
07/5/85

8507170517 850705
PDR ADOCK 05000440
S PDR

JUL 05 1985

Mr. Murray R. Edelman
The Cleveland Electric
Illuminating Company

Perry Nuclear Power Plant
Units 1 and 2

cc:

Jay Silberg, Esq.
Shaw, Pittman, & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20006

Mr. Larry O. Beck
The Cleveland Electric
Illuminating Company
P. O. Box 97 E-210
Perry, Ohio 44081

Donald H. Hauser, Esq.
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Resident Inspector's Office
U. S. Nuclear Regulatory Commission
Parmly at Center Road
Perry, Ohio 44081

Regional Administrator, Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Donald T. Ezzone, Esq.
Assistant Prosecuting Attorney
105 Main Street
Lake County Administration Center
Painesville, Ohio 44077

Ms. Sue Hiatt
OCRE Interim Representative
8275 Munson
Mentor, Ohio 44060

Terry J. Lodge, Esq.
618 N. Michigan Street
Suite 105
Toledo, Ohio 43624

John G. Cardinal, Esq.
Prosecuting Attorney
Ashtabula County Courthouse
Jefferson, Ohio 44047