

OPERATING DATA REPORT

DOCKET NO. 50-133
 DATE 4-2-85
 COMPLETED BY CC KwoK
 TELEPHONE 707/443-2787

OPERATING STATUS

1. Unit Name: HUMBOLDT BAY POWER PLANT - UNIT 3
2. Reporting Period: MARCH
3. Licensed Thermal Power (MWt): 220
4. Nameplate Rating (Gross MWe): 65
5. Design Electrical Rating (Net MWe): 65
6. Maximum Dependable Capacity (Gross MWe): 65
7. Maximum Dependable Capacity (Net MWe): 63
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes

N/A

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>744</u>	<u>2160</u>	<u>189,935</u>
12. Number Of Hours Reactor Was Critical	<u>0</u>	<u>0</u>	<u>98171</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line	<u>0</u>	<u>0</u>	<u>97252</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>15,618,456</u>
17. Gross Electrical Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>4,739,732</u>
18. Net Electrical Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>4,533,964</u>
19. Unit Service Factor	<u>0</u>	<u>0</u>	<u>51.2%</u>
20. Unit Availability Factor	<u>0</u>	<u>0</u>	<u>51.2%</u>
21. Unit Capacity Factor (Using MDC Net)	<u>0</u>	<u>0</u>	<u>37.9%</u>
22. Unit Capacity Factor (Using DER Net)	<u>0</u>	<u>0</u>	<u>36.7%</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>0</u>	<u>1.91%</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

N/A

25. If Shut Down At End Of Report Period, Estimated Date of Startup: DECOMMISSIONING

26. Units In Test Status (Prior to Commercial Operation):

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

Forecast

Achieved

B506070253 B50331
 PDR ADOCK 05000133
 R PDR

IE24
 41

(9/77)

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH MARCH

DOCKET NO. 50-133
 UNIT NAME HBPP #3
 DATE 4-2-85
 COMPLETED BY CCKWCK
 TELEPHONE 707/443-2787

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
76-6	760702	S	744	C, H	1	N/A	—	—	SEISMIC MODIFICATIONS

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance of Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets for Licensee
 Event Report (LER) File (NUREG-
 0161)

⁵
 Exhibit I - Same Source

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-133

UNIT HBPP #3

DATE 4-2-85

COMPLETED BY CCKWOK

TELEPHONE 707/443-2787

MONTH MARCH

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	0
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	
18	
19	
20	
21	
22	
23	
24	
25	
26	
27	
28	
29	
30	
31	

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

PACIFIC GAS AND ELECTRIC COMPANY

PG&E

1034 SIXTH STREET • EUREKA, CALIFORNIA 95501 • (707) 443-2787

E. D. WEEKS

PLANT MANAGER

NUCLEAR PLANT OPERATIONS - HUMBOLDT

March 9, 1985

Office of Management Information
and Program Control
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Re: Docket No. 50-133
License No. DPR-7

Gentlemen:

Enclosed are the completed monthly report forms and the narrative of operating and major maintenance experience for Humboldt Bay Power Plant Unit No. 3 (HBPP-Unit 3) for March, 1985. These forms and the narrative are submitted in accordance with Section IX I.1.c of our Technical Specifications.

Sincerely,

ED Weeks

E. D. Weeks
Plant Manager
Humboldt Bay Power Plant
1034 Sixth Street
Eureka, California 95501
(707-443-2787)

Enclosure

cc: Mr. J. C. Carroll
Mr. B. S. Lew
Mr. J. D. Shiffer

Mr. John B. Martin
Regional Administrator
U. S. Nuclear Regulatory Commission
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

EDWeeks:mc

IE2A
11

MONTHLY NARRATIVE REPORT
OF OPERATING
AND MAJOR MAINTENANCE EXPERIENCE

This report describes the operating and major maintenance experience for the month of March 1985. This report was prepared by the Plant Staff and is submitted in accordance with Section IX:I.1.c. of the Technical Specifications.

During the report period, the reactor has been in the cold shutdown mode with the core unloaded and the reactor vessel drained. During the month, work continued on the layup of equipment not required by this operating mode, plant decontamination, and preparations for decommissioning. A project for solidification of liquid radioactive wastes was commenced. No other significant maintenance was accomplished during the month.