

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)
JAMES A. FITZPATRICK NUCLEAR POWER PLANTDOCKET NUMBER (2)
0 5 0 0 0 3 3 3 1 OF 0 1

TITLE (4)

Reactor Scram While Shutdown

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)														
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)												
0	5	0	3	8	5	8	5	0	1	2	0	0	0	5	3	0	8	5	0	5	0	0	0

OPERATING MODE (9)		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)										
POWER LEVEL (10)	0 0 0	20.402(b)			20.406(c)			<input checked="" type="checkbox"/> 50.73(a)(2)(iv)			75.71(b)	
		20.406(a)(1)(i)			50.36(e)(1)			<input type="checkbox"/> 50.73(a)(2)(v)			73.71(e)	
		20.406(a)(1)(ii)			50.36(e)(2)			<input type="checkbox"/> 50.73(a)(2)(vii)			OTHER (Specify in Abstract below and in Text, NRC Form 365A)	
		20.406(a)(1)(iii)			50.73(a)(2)(ii)			<input type="checkbox"/> 50.73(a)(2)(viii)(A)				
		20.406(a)(1)(iv)			50.73(a)(2)(ii)			<input type="checkbox"/> 50.73(a)(2)(viii)(B)				
20.406(a)(1)(v)			50.73(a)(2)(iii)			<input type="checkbox"/> 50.73(a)(2)(ix)						

LICENSEE CONTACT FOR THIS LER (12)

NAME	TELEPHONE NUMBER
Douglas J. Lindsey, Assistant Operations Superintendent	AREA CODE 3 1 5 3 4 2 - 3 8 4 0

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPDOS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPDOS

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE)	NO	EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR
<input checked="" type="checkbox"/>	<input type="checkbox"/>				

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

During a scheduled outage for maintenance, two reactor scrams occurred within an approximate period of eight hours. At the time of the first event, the operators were performing a valve lineup on instrument root valves for reactor pressure vessel level instruments. The instruments that generate the low level signal to the reactor protection system were improperly valved in, causing the level instrument to sense a false low level signal and generate a trip signal to the reactor protection system.


In the second scram event, a false low reactor level signal generated a reactor scram due to an Instrument Technician backfilling an instrument line which is common with the instruments which generate a scram on reactor vessel low level.

The initial action was to reset the scrams. The operators and technicians involved were counselled on the events.

8506070310 850530
PDR ADOCK 0500333
S PDR

James A. FitzPatrick
Nuclear Power Plant
P.O. Box 41
Lycoming, New York 13093
315 342.3840

Harold A. Glovier
Resident Manager



JAFP-85-0472
May 30, 1985


United States Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

REFERENCE: DOCKET NO. 50-333 Licensee Event Report: 85-012-00

Dear Sir:

Enclosed please find the referenced Licensee Event Report in accordance with the requirements of 10 CFR 50.73.

If there are any questions concerning this report, please contact Mr. Douglas J. Lindsey at (315) 342-3840, Extension 302.


HAROLD A. GLOVIER

HAG:DJL:kjm

Enclosure

cc: USNRC, Region I (1)
INPO Records Center, Atlanta, Georgia (1)
Internal Power Authority Distribution
American Nuclear Insurers (1)
NRC Resident Inspector
Document Control Center
LER/OR File

IE22
11