

OPERATING DATA REPORT

DOCKET NO. 50-302
 DATE 7/1/85
 COMPLETED BY D. Graham
 TELEPHONE (904) 795-3802

OPERATING STATUS

1. Unit Name: Crystal River Unit 3
2. Reporting Period: 6/1/85 - 6/30/85
3. Licensed Thermal Power (MWt): 2544
4. Nameplate Rating (Gross MWe): 890
5. Design Electrical Rating (Net MWe): 825
6. Maximum Dependable Capacity (Gross MWe): 860
7. Maximum Dependable Capacity (Net MWe): 821
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:
NA

Notes

9. Power Level To Which Restricted, If Any (Net MWe): NA
10. Reasons For Restrictions, If Any: NA

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	720	4343	72767
12. Number Of Hours Reactor Was Critical	0	1608.3	47524
13. Reactor Reserve Shutdown Hours	0	0	1280.3
14. Hours Generator On-Line	0	1606.5	46524.3
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Energy Generated (MWH)	0	2924173	104586058
17. Gross Electrical Energy Generated (MWH)	0	1014639	35741856
18. Net Electrical Energy Generated (MWH)	0	954730	33950741
19. Unit Service Factor	0%	37.0%	63.9%
20. Unit Availability Factor	0%	37.0%	63.9%
21. Unit Capacity Factor (Using MDC Net)	0%	26.8%	58.7%
22. Unit Capacity Factor (Using DER Net)	0%	26.6%	56.6%
23. Unit Forced Outage Rate	0%	0%	19.6%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

Refueling outage which began 3/9/85 and is scheduled to last 20 weeks.

25. If Shut Down At End Of Report Period, Estimated Date of Startup: July 27, 1985

26. Units In Test Status (Prior to Commercial Operation):

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

Forecast	Achieved
_____	1/14/77
_____	1/30/77
_____	3/13/77

8507180289 850630
 PDR ADOCK 05000302
 R PDR

TE24
 11

(9/77)

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-302

UNIT FLCRP-3

DATE 7/1/85

COMPLETED BY D. Graham

TELEPHONE (904) 795-3802

MONTH June 1985

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	0
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	0
18	
19	
20	
21	
22	
23	
24	
25	
26	
27	
28	
29	
30	
31	

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH 6/85

DOCKET NO. 50-302
UNIT NAME FLCRP-3
DATE 7/2/85
COMPLETED BY S. Stewart
TELEPHONE (904) 795-3802

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
85-07	850308	S	720	C	4	NA	NA	NA	Refueling outage continues.

¹
F: Forced
S: Scheduled

²
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

³
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

⁴
Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File (NUREG-
0161)

⁵
Exhibit I - Same Source

MONTHLY OPERATIONAL SUMMARY STATEMENT

DOCKET NO. 50-302

UNIT FLCRP-3


DATE 7/2/85

COMPLETED BY S. Stewart

TELEPHONE (904) 795-3802

MONTH June 1985

SUMMARY STATEMENT: Crystal River 3 remains off-line for refueling and maintenance.



**Florida
Power**
CORPORATION

July 8, 1985
3F0785-10

Mr. James M. Taylor, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: Crystal River Unit 3
Docket No. 50-302
Operating License No. DPR-72
Monthly Operating Report

Dear Sir:

Attached are twelve (12) copies of the Crystal River Unit 3 June 1985 Monthly Operating Report. These reports are submitted in accordance with Technical Specification 6.9.1.6.

Sincerely,

G. R. Westafer
Manager, Nuclear Operations
Licensing and Fuel Management

AEF/feb

Attachments

cc: Dr. J. Nelson Grace
Regional Administrator, Region II
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
101 Marietta Street N.W., Suite 2900
Atlanta, GA 30323