



A Centerior Energy Company

EDISON PLAZA
300 MADISON AVENUE
TOLEDO, OHIO 43652-0001

August 20, 1996

Ms. Elizabeth Wick, Group Leader
Ohio Environmental Protection Agency
Northwest District Office
347 North Dunbridge Road
Bowling Green, Ohio 43402

Dear Ms. Wick:

Subject: Submittal of the July 1996 Telecommunicated Hardcopy Wastewater Report

Attached is a hardcopy of the telecommunicated July 1996 Wastewater Report for the Davis-Besse Nuclear Power Station (DBNPS), Unit Number 1, Permit Number 2IB00011*FD. Also attached is an update to our facility information, as requested.

If you have any questions, please contact Mr. James L. Freels, Manager - Regulatory Affairs, at (419) 321-8466.

Sincerely yours,

James H. Lash / *J. L. Michaelis*

James H. Lash
Plant Manager
Davis-Besse Nuclear Power Station

TKW/lkm

Attachments

cc: Z. A. Clayton, Ohio Environmental Protection Agency
U. S. Nuclear Regulatory Commission Document Control Desk

9610030160 960731
PDR ADOCK 05000346
R PDR

020022

DE 25
11

TOLEDO EDISON/DAVIS-BESSE

2IB00011001 JUL 1996

1 1 08/08/96 2IB0001

300 MADISON AV. MSTOP 2101 001 DISCHARGE TO LAKE ERIE
TOLEDO 43652 OTTAWA

FORM

TOLEDO EDISON

T. WASCH

1 999	3 001	1 999	3 001
WATER TEMP. F	PH S.U.	CONDUIT FLOW MGD	CHLORINE FREE A MG/L

00011	00400	50050	50064
-------	-------	-------	-------

01	78.6	8.7	28.6	AA
02	78.5	8.6	27.6	AA
03	76.6	8.6	28.4	AA
04	74.8	8.7	28.9	AA
05	75.2	8.6	28.9	AA
06	76.8	AH	28.8	AH
07	78.2	AH	30.2	AH
08	78.3	8.7	29.4	AA
09	76.2	8.7	28.9	AA
10	74.2	8.7	29.2	AA
11	72.3	8.7	28.8	AA
12	76.2	8.7	30.4	AA
13	76.8	AH	30.3	AH
14	77.0	AH	29.4	AH
15	77.0	8.8	29.4	AA
16	78.0	8.8	28.8	AA
17	78.1	8.8	28.8	AA
18	78.7	8.8	28.8	AA
19	79.2	8.8	28.8	AA
20	74.7	AH	29.2	AH
21	74.5	AH	28.9	AH
22	74.9	8.7	28.7	AA
23	76.3	8.6	30.4	AA
24	77.1	8.6	28.5	AA
25	76.4	8.6	28.4	AA
26	75.9	8.6	28.4	AA
27	75.3	AH	30.6	AH
28	75.6	AH	30.0	AH
29	76.5	8.6	29.1	AA
30	75.8	8.7	28.5	AA
31	74.5	8.7	28.4	AA

2368.2	199.80	901.50	AA
76.394	8.6870	29.081	AA
79.200	8.8000	30.600	AA
72.300	8.6000	27.600	AA

AA: The Total Chlorine detection limit is 0.01 mg/L using the direct amperometric method.

REPORTER

08/08/96

T. Wasch

Plant Manager

2IB00011001



TOLEDO EDISON/DAVIS-BESSE

2IB00011002 JUL 1996

1 1 08/08/96 2IB00011

300 MADISON AV. MSTOP 2101 002 OUTFALL TOUSSAINT RIVER
TOLEDO 43652 OTTAWA

FORM

TOLEDO EDISON

T. WASCH

3	3	3	1
001	001	001	999
PH	RESIDU	OIL GR	CONDUI
S.U.	TOT NF	TOTAL	FLOW
	MG/L	MG/L	MGD
00400	00530	00550	50050

01
02
03
04
05
06
07
08
09
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31

0.0000	0.0000	0.0000	0.0000
0.0000	0.0000	0.0000	0.0000
0.0000	0.0000	0.0000	0.0000
0.0000	0.0000	0.0000	0.0000

AM: No flow; the discharge gate was closed throughout
July 1996.



1 1 08/08/96 2IB0001

FORM

T. WASCH

53.000	6.8820
53.000	0.2220
53.000	0.2220
53.000	0.2220

[illegible]

FORM

T. WASCH

Table 1. *Continued*

TOLEDO EDISON/DAVIS-BESSE

2IB00011602 JUL 1996

1 1 08/08/96 2IB0001

300 MADISON AV. MSTOP 2101
TOLEDO 43652 OTTAWA

602 LOW VOLUME WW SETTLING BASIN OVERFLOW

FORM

TOLEDO EDISON

T. WASCH

	1 999	3 001	3 001
	CONDUIT FLOW MGD	RESIDU TOT NF MG/L	OIL GR TOTAL MG/L
	50050	00530	00550
01	.238		
02	.238		
03	.238	6	
04	.238		
05	.238		2
06	.238		
07	.238		
08	.238		
09	.238		
10	.238		
11	.238		
12	.238		
13	.238		
14	.238		
15	.238		
16	.238		
17	.238	AA	
18	.238		1
19	.238		
20	.238		
21	.238		
22	.238		
23	.238		
24	.238		
25	.238		
26	.238		
27	.238		
28	.238		
29	.238		
30	.238		
31	.238		
	7.3780	6.0000	3.0000
	0.2380	3.0000	1.5000
	0.2380	6.0000	2.0000
	0.2380	AA	1.0000

AA: The Total Non-filterable Residue detection limit is
1.0 mg/L using the gravimetric method.

REPORTER

T.H. Loch / L.L. Mucke

Plant Manager

2IB00011602



TOLEDO EDISON/DAVIS-BESSE

2IB00011801 JUL 1996

1 1 08/08/96 2IB0001

300 MADISON AV. MSTOP 2101 801 INTAKE PRIOR COOLING OPERATION
TOLEDO 43652 OTTAWA

FORM

TOLEDO EDISON

T. WASCH

1

999

WATER
TEMP.
F

00011

01	76.0
02	76.7
03	76.0
04	73.7
05	73.8
06	74.3
07	74.9
08	75.9
09	75.6
10	73.6
11	73.1
12	73.0
13	73.1
14	73.8
15	74.6
16	74.5
17	74.7
18	75.0
19	75.4
20	73.8
21	73.5
22	73.1
23	73.8
24	74.7
25	74.5
26	73.5
27	73.5
28	73.8
29	73.7
30	73.3
31	72.8

2301.7
74.248
76.700
72.800

REPORTER

08/20/96

J. H. Lach / R. L. Mikulski

Plant Manager

2IB00011801

