

OPERATING DATA REPORT

DOCKET NO. 50-244

DATE April 19, 1985

COMPLETED BY Andrew E. McNamara
Andrew E. McNamara

TELEPHONE (315) 524-4446 Ext. 301

OPERATING STATUS

1. Unit Name: GINNA STATION, UNIT #1
2. Reporting Period: March, 1985
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes

The unit was taken out of service on March 2, 1985 at 0030 hours for Annual Refueling and Maintenance

9. Power Level to Which Restricted, If Any (Net MWe):
10. Reasons For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	744.00	2,160.00	134,520.00
12. Number of Hours Reactor Was Critical	25.03	1,441.03	101,889.74
13. Reactor Reserve Shutdown Hours	0	0	1,687.55*
14. Hours Generator On-Line	24.5	1,440.50	99,732.80
15. Unit Reserve Shutdown Hours	0	0	8.5*
16. Gross Thermal Energy Generated (MWH)	27,648	2,119,608	138,405,369
17. Gross Electrical Energy Generated (MWH)	8,695	703,221	45,188,628
18. Net Electrical Energy Generated (MWH)	8,133	668,294	42,881,315
19. Unit Service Factor	3.29%	66.69%	74.14%
20. Unit Availability Factor	3.29%	66.69%	74.15%
21. Unit Capacity Factor (Using MDC Net)	2.3%	65.83%	69.44%**
22. Unit Capacity Factor (Using DER Net)	2.3%	65.83%	69.44%**
23. Unit Forced Outage Rate	0	0	7.64
24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):			

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

**Corrects calculating error in previously submitted report.

8506070520 850419
PDR ADOCK 05000244
R PDR

49-88 (REV. 1/78)
IEa4
41