

APR 09 1985

General Electric Company  
ATTN: Mr. Eugene A. Lees, General Manager  
Nuclear Fuel Manufacturing Department  
P. O. Box 780  
Wilmington, NC 28402

Gentlemen:

SUBJECT: REPORT NO. 70-1113/84-15

Thank you for your response of March 7, 1985, to our Notice of Violation issued on February 7, 1985, concerning activities conducted at your Wilmington Manufacturing Department facility under NRC License No. SNM-1097. We have evaluated your response and found that it does not meet the requirements of 10 CFR 2.201 in that you have not specified definitive actions to assure that radioactive contamination is promptly detected, reported and effectively removed and decontaminated areas are promptly and thoroughly surveyed. You note that the contamination was not observed or detected during two surveys, one of which was performed with an NRC inspector present. Your letter appears to be in error in that the inspector did not accompany the technician into the LEA room for the survey performed on the morning of November 28, 1984.

Therefore, please provide us, within 30 days of the date of this letter, with a written statement of the actions you have taken or plan to take to correct and prevent recurrence of this violation and the date when full compliance will be achieved.

We appreciate your cooperation in this matter.

Sincerely,

J. Philip Stohr, Director  
Division of Radiation Safety  
and Safeguards

cc: C. M. Vaughan, Manager  
Regulatory Compliance

bcc: Document Control Desk  
Safeguards and Materials Program  
Branch, EWW-359  
Fuel Facility Safeguards Licensing  
Branch, 881-SS  
License Fee Management Branch  
State of North Carolina

RII  
*EC*  
EClay:bhg  
3/21/85

RII  
*EC*  
JKahle  
3/21/85

RII  
*EM*  
EMcAlpine  
4/2/85

RII  
*KB*  
KBarr  
4/2/85

RII  
*J*  
JPuckett  
4/9/85

*smc*  
*for PS*  
4/9/85

8507180601 850409  
PDR ADDCK 07001113  
C PDR

IEO1 10