



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

COMMONWEALTH EDISON COMPANY

DOCKET NO. 50-295

ZION NUCLEAR POWER STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 173  
License No. DPR-39


1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Commonwealth Edison Company (the licensee) dated September 3, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-39 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 173, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Clyde Y. Shiraki, Senior Project Manager  
Project Directorate III-2  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: October 29, 1996



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

COMMONWEALTH EDISON COMPANY

DOCKET NO. 50-304

ZION NUCLEAR POWER STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 160  
License No. DPR-48


1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Commonwealth Edison Company (the licensee) dated September 3, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-48 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 160 , are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Clyde Y. Shiraki, Senior Project Manager  
Project Directorate III-2  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: October 29, 1996

ATTACHMENT TO LICENSE AMENDMENT NOS. 173 AND 160

FACILITY OPERATING LICENSE NOS. DPR-39 AND DPR-48

DOCKET NOS. 50-295 AND 50-304

Revise the Appendix A Technical Specifications by removing the page identified below and inserting the attached page. The revised page is identified by the captioned amendment number and contains marginal lines indicating the area of change.

Remove Page

74f3

Insert Page

74f3

LIMITING CONDITION FOR OPERATION	SURVEILLANCE REQUIREMENT
	<p>10. <u>Repaired Tube</u> means a tube that has undergone a process that re-establishes its serviceability. The sleeving process utilized shall be one of the following:</p> <ul style="list-style-type: none"> <li>a. The Combustion Engineering welded sleeve process as described in Report CEN-331-P, Revision 1-P.**</li> <li>b. The Westinghouse Electric Corporation mechanical sleeve process as described in Report WCAP-11669.</li> <li>c. The Bechtel-KWU Alliance welded sleeve process as described in Report BKAT-01-P, Revision 1.</li> </ul> <p>11. <u>F* Distance</u> is the length of undegraded tube required to resist pullout. This distance is measured from the bottom of the upper hardroll transition toward the bottom of the tubesheet and has been conservatively determined to be 1.05 inches (not including eddy current uncertainty).#</p> <p>12. <u>F* Tube</u> is a tube with indications below the F* Distance, equal to or greater than 40%, and no indications within the F* Distance.</p> <p>**The following sections of ABB/CE Report CEN-629-P Revision 00 shall be implemented in conjunction with Report CEN-331-P, Revision 1-P:</p> <ul style="list-style-type: none"> <li>Section 4.5.3 - Tube Brushing-Cleaning Equipment</li> <li>Section 4.5.7 - Nondestructive Examination</li> <li>Section 5.0 - Sleeve Examination Program</li> <li>Section 9.3.1 - Cleaning Qualification</li> </ul> <p># Valid for Z1R14 and thru Z1C15.</p>