

October 31, 1996

No. 96-106
EA No. 96-346

**U.S. NUCLEAR REGULATORY COMMISSION
REGION I
NOTICE OF SIGNIFICANT LICENSEE MEETING**

Licensee: PECO Energy

Facility: Peach Bottom Atomic Power Station

Docket Nos.: 50-277 & 50-278

Time and Date: 1:00 p.m., Wednesday, December 11, 1996

Location: NRC Region I
475 Allendale Rd.
King of Prussia, PA 19406
Public Meeting Room

Purpose: Predecisional Enforcement Conference to discuss interactions that were introduced during prior modifications, between emergency diesel generators and associated residual heat removal system pumps.

NRC Attendees: H. Miller, Regional Administrator, NRC Region I
R. Crlenjak, Acting Deputy Director, Division of Reactor Projects (DRP)
R. Blough, Deputy Director, Division of Reactor Safety (DRS)
W. Pasciak, Chief, Projects Branch 4, DRP
W. Ruiand, Chief, Electrical Engineering Branch, DRS
W. Schmidt, Senior Resident Inspector, Peach Bottom, DRP
R. Lorson, Resident Inspector, Peach Bottom, DRP
P. Swetland, Project Engineer, DRP
J. Stolz, Director, Project Directorate I-2, Office of Nuclear Reactor Regulation (NRR)
J. Shea, Project Manager, Peach Bottom, NRR

Licensee Attendees: D. Smith, President, PECO Nuclear
G. Edwards, Plant Manager, Peach Bottom, PECO Nuclear
G. Hunger, Director, Licensing, PECO Nuclear
M. Warner, Director, Site Engineering, PECO Nuclear
P. Davison, Site Engineering Supervisor, PECO Nuclear

Note: This meeting is closed to the public. Attendance by additional NRC personnel, including handicapped persons requiring assistance, should be made known by December 5, 1996, via telephone call to Walt Pasciak at (610) 337-5258.

Approved By: 

Walter J. Pasciak, Chief
Projects Branch 4
Division of Reactor Projects

9611050249 961031
PDR ADOCK 05000277
G PDR

IE45 1/0