

October 31, 1996

Mr. Donald F. Schnell  
Senior Vice President - Nuclear  
Union Electric Company  
Post Office Box 149  
St. Louis, Missouri 63166

SUBJECT: EVALUATION OF THE SECOND 10-YEAR INTERVAL INSERVICE TESTING PROGRAM  
REQUESTS FOR RELIEF - CALLAWAY PLANT, UNIT 1 (TAC NO. M95475)

Dear Mr. Schnell:

By letter dated May 22, 1996, Union Electric Company, the licensee for the Callaway Plant, submitted revised relief requests to the inservice testing program. The revised program included changes made in response to the NRC's safety evaluation dated June 2, 1995, for the second 10-year inservice testing program interval. The staff has completed its review of the proposed program relief requests. The basis for the staff's conclusions are contained in the attached safety evaluation.

The staff has determined that the proposed testing for Requests for Relief P-02, EN-02, and EN-05, provides reasonable assurance of operational readiness of the subject systems and that the Code examination requirements are impractical. Therefore, relief is granted pursuant to 10 CFR 50.55a(f)(6)(i). The granting of such relief is authorized by law, giving due consideration to the burden upon the licensee that could result if the Code requirements were imposed on the facility.

Sincerely,

Original signed by:

William H. Bateman, Director  
Project Directorate IV-2  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-483

Enclosure: Safety Evaluation

cc w/encl: See next page

9611060213 961031  
PDR ADOCK 05000483  
P PDR

DISTRIBUTION:

Docket File  
PUBLIC  
JRoe  
EGAl  
WBateman  
KThomas  
RWessman, EMEB  
JMitchell  
ACRS, TWFN  
PDIV-2 Reading  
OGC, 015B18  
WJohnson, RIV  
JDyer, RIV  
EPeyton  
GHill (2)

DOCUMENT NAME: CAL95475.REL

OFC	PDIV-2/PM	PDIV-2/LA	BC/EMEB	OGC	PDIV-2/PD
NAME	KThomas:ye	EPeyton	RWessman	11/7/96	WBateman
DATE	10/10/96	10/10/96	10/11/96	10/24/96	10/31/96

OFFICIAL RECORD COPY

060065

NRC FILE CENTER COPY

October 31, 1996

Mr. Donald F. Schnell  
Senior Vice President - Nuclear  
Union Electric Company  
Post Office Box 149  
St. Louis, Missouri 63166

SUBJECT: EVALUATION OF THE SECOND 10-YEAR INTERVAL INSERVICE TESTING PROGRAM  
REQUESTS FOR RELIEF - CALLAWAY PLANT, UNIT 1 (TAC NO. M95475)

Dear Mr. Schnell:

By letter dated May 22, 1996, Union Electric Company, the licensee for the Callaway Plant, submitted revised relief requests to the inservice testing program. The revised program included changes made in response to the NRC's safety evaluation dated June 2, 1995, for the second 10-year inservice testing program interval. The staff has completed its review of the proposed program relief requests. The basis for the staff's conclusions are contained in the attached safety evaluation.

The staff has determined that the proposed testing for Requests for Relief P-02, EN-02, and EN-05, provides reasonable assurance of operational readiness of the subject systems and that the Code examination requirements are impractical. Therefore, relief is granted pursuant to 10 CFR 50.55a(f)(6)(i). The granting of such relief is authorized by law, giving due consideration to the burden upon the licensee that could result if the Code requirements were imposed on the facility.

Sincerely,

Original signed by:

William H. Bateman, Director  
Project Directorate IV-2  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-483

Enclosure: Safety Evaluation

cc w/encl: See next page

DISTRIBUTION:

Docket File	ACRS, TWFN
PUBLIC	PDIV-2 Reading
JRoe	OGC, 015B18
EGAl	WJohnson, RIV
WBateman	JDyer, RIV
KThomas	EPeyton
<del>RWessman, EMED</del>	GHill (2)
JMitchell	

DOCUMENT NAME: CAL95475.REL

OFC	PDIV-2/PM	PDIV-2/LA	BC/EMEB	OGC 14	PDIV-2/PD
NAME	KThomas:ye	EPeyton	RWessman	11/1/96	WBateman
DATE	10/10/96	10/10/96	10/11/96	10/11/96	10/31/96

OFFICIAL RECORD COPY

2 10/10  
EW

cc w/encl:

Professional Nuclear  
Consulting, Inc.  
19041 Raines Drive  
Derwood, Maryland 20855

Gerald Charnoff, Esq.  
Thomas A. Baxter, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N. Street, N.W.  
Washington, D.C. 20037

Mr. H. D. Bono  
Supervising Engineer,  
Site Licensing  
Union Electric Company  
Post Office Box 620  
Fulton, Missouri 65251

U.S. Nuclear Regulatory Commission  
Resident Inspector Office  
8201 NRC Road  
Steedman, Missouri 65077-1302

Mr. G. L. Randolph, Vice President  
Nuclear Operations  
Union Electric Company  
P.O. Box 620  
Fulton, Missouri 65251

Manager - Electric Department  
Missouri Public Service Commission  
301 W. High  
Post Office Box 360  
Jefferson City, Missouri 65102

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
Harris Tower & Pavilion  
611 Ryan Plaza Drive, Suite 400  
Arlington, Texas 76011-8064

Mr. Ronald A. Kucera, Deputy Director  
Department of Natural Resources  
P.O. Box 176  
Jefferson City, Missouri 65102

Mr. Neil S. Carns  
President and Chief Executive Officer  
Wolf Creek Nuclear Operating Corporation  
P.O. Box 411  
Burlington, Kansas 66839

Mr. Dan I. Bolef, President  
Kay Drey, Representative  
Board of Directors Coalition  
for the Environment  
6267 Delmar Boulevard  
University City, Missouri 63130

Mr. Lee Fritz  
Presiding Commissioner  
Callaway County Court House  
10 East Fifth Street  
Fulton, Missouri 65151

Mr. Alan C. Passwater, Manager  
Licensing and Fuels  
Union Electric Company  
Post Office Box 149  
St. Louis, Missouri 63166

Mr. J. V. Laux, Manager  
Quality Assurance  
Union Electric Company  
Post Office Box 620  
Fulton, Missouri 65251