

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Gordova, IL 61242-9740
Tel 309-654-2241



ESK 96-200

October 30, 1996

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Reference: (a) E. S. Kraft, Jr. letter to USNRC, dated October 2, 1996
(b) J. Schrage letter to USNRC, dated August 30, 1994

Subject: Quad Cities Station Units 1 and 2;
NRC Docket Numbers 50-254 and 50-265;
Completion of Generic Letter 89-19 Actions

The purpose of this letter is to provide the final status of recommendations made in Generic Letter (GL) 89-19, "Request for Action Related to Resolution of Unresolved Safety Issue A-47 'Safety Implication of Control Systems in LWR Nuclear Power Plants' Pursuant to 10CFR50.54(f)."

The Technical Specification Upgrade Program (Reference (a)) implemented the Limiting Conditions for Operation and Surveillance Requirements (Reference (b)) that provide trips of the Reactor Feedwater Pumps on high reactor water level. This completed the remaining action to satisfy GL 89-19 requirements. If you have any questions concerning this letter, please contact Mr. Charles Peterson, Regulatory Affairs Manager, at (309) 654-2241, extension 3602.

Sincerely,

E. S. Kraft, Jr.
Site Vice President
Quad Cities Station

cc: A. B. Beach, NRC Regional Administrator, RIII
R. M. Pulsifer, NRC Project Manager, NRR
C. G. Miller, Senior Resident Inspector, Quad Cities
D. C. Tubbs, MidAmerican Energy Company
R. J. Singer, MidAmerican Energy Company
Office of Nuclear Facility Safety, IDNS
Document Control Desk, Licensing (electronic and hard copies)

ADD 1%

9611060219 961030
PDR ADOCK 05000254
P PDR