

November 5, 1996

Mr. Douglas R. Gipson  
Senior Vice President  
Nuclear Generation  
Detroit Edison Company  
6400 North Dixie Highway  
Newport, Michigan 48166

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION RELATED TO THE AMENDMENT TO  
EXTEND EMERGENCY DIESEL GENERATOR ALLOWED OUTAGE TIMES AT FERMI 2  
(TAC NO. M94171)

Dear Mr. Gipson:

On November 22, 1995, Detroit Edison submitted an amendment request to extend the allowed outage times for the emergency diesel generators for NRC staff review. Detroit Edison provided supplemental information related to the amendment request in letters dated February 19, 1996, April 19, 1996, and May 3, 1996. Additional information, as discussed in the enclosure, is requested in order for the staff to complete its review. We request that you respond within 30 days.

If you have any questions concerning this request, please contact me at (301) 415-2828.

Sincerely,

Original signed by  
Andrew J. Kugler, Project Manager  
Project Directorate III-1  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-341

Enclosure: As stated

cc w/encl: See next page

DISTRIBUTION:

Docket File OGC  
PUBLIC ACRS  
PD31 Reading File  
MJordan, RIII  
AVegel, RIII  
JRoe  
EAdensam (EGA1)  
lJung  
PKang

DOCUMENT NAME: G:\WPDOCS\FERMI\FE94171.RAI

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PD31	E	LA:PD31	E	C:SPSB	E	D:PD31
NAME	AKugler		CJamerson		EButcher		JHannon
DATE	10/31/96		10/31/96		11/4/96		11/5/96

OFFICIAL RECORD COPY

9611060264 961105  
PDR ADOCK 05000341  
P PDR

NRC FILE CENTER COPY



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

November 5, 1996

Mr. Douglas R. Gipson  
Senior Vice President  
Nuclear Generation  
Detroit Edison Company  
6400 North Dixie Highway  
Newport, Michigan 48166

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION RELATED TO THE AMENDMENT TO  
EXTEND EMERGENCY DIESEL GENERATOR ALLOWED OUTAGE TIMES AT FERMI 2  
(TAC NO. M94171)

Dear Mr. Gipson:

On November 22, 1995, Detroit Edison submitted an amendment request to extend the allowed outage times for the emergency diesel generators for NRC staff review. Detroit Edison provided supplemental information related to the amendment request in letters dated February 19, 1996, April 19, 1996, and May 3, 1996. Additional information, as discussed in the enclosure, is requested in order for the staff to complete its review. We request that you respond within 30 days.

If you have any questions concerning this request, please contact me at (301) 415-2828.

Sincerely,

*Dinda R. Lundrum*  
for Andrew J. Kugler, Project Manager  
Project Directorate III-1  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-341

Enclosure: As stated

cc w/encl: See next page

Mr. Douglas R. Gipson  
Detroit Edison Company

Fermi-2

cc:

John Flynn, Esquire  
Senior Attorney  
Detroit Edison Company  
2000 Second Avenue  
Detroit, Michigan 48226

Drinking Water and Radiological  
Protection Division  
Michigan Department of  
Environmental Quality  
3423 N. Martin Luther King Jr Blvd  
P. O. Box 30630 CPH Mailroom  
Lansing, Michigan 48909-8130

U.S. Nuclear Regulatory Commission  
Resident Inspector's Office  
6450 W. Dixie Highway  
Newport, Michigan 48166

Monroe County Emergency Management  
Division  
963 South Raisinville  
Monroe, Michigan 48161

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
801 Warrenville Road  
Lisle, Illinois 60532-4351

Peter W. Smith  
Director, Nuclear Licensing  
Detroit Edison Company  
Fermi-2 - 270 TAC  
6400 North Dixie Highway  
Newport, Michigan 48166

REQUEST FOR ADDITIONAL INFORMATION RELATED TO  
THE AMENDMENT TO EXTEND EMERGENCY DIESEL GENERATOR  
ALLOWED OUTAGE TIMES AT FERMI 2 (TAC NO. M94171)

The May 3, 1996, supplemental submittal indicated that a risk matrix has been developed and is used to identify the risk associated with maintenance activities at power. Provide the following information for NRC staff review:

- (1) a general description of the risk matrix, focusing on capabilities and limitations,
- (2) a list of systems that are modeled in the risk matrix,
- (3) a description on how risk information from your PRA is incorporated into the risk matrix, and
- (4) a brief description of your procedure(s) to implement the use of risk matrix.

ENCLOSURE