

Docket No. 50-344

July 11, 1985

DLR
014

Mr. Bart D. Withers
Vice President Nuclear
Portland General Electric Company
121 S.W. Salmon Street
Portland, Oregon 97204

Dear Mr. Withers:

Subject: SAFETY EVALUATION FOR GENERIC LETTER 83-28, ITEM 4.5.1

Enclosed is the staff's Safety Evaluation addressing Reactor Trip System Reliability (System Functional Testing), Item 4.5.1 of Generic Letter 83-28.

Based on Portland General Electric's (PGE) commitment to modify the reactor trip breakers to allow automatic actuation of the shunt trip, provide for independent on-line testing of the undervoltage and shut trip mechanisms, and include such testing in the procedure used for monthly testing of the Reactor Protection System, the staff concludes that PGE has satisfactorily completed the actions required by Item 4.5.1 of Generic Letter 83-28.

Sincerely,

/S/

Edward J. Butcher, Acting Chief
Operating Reactors Branch No. 3
Division of Licensing

Enclosure:
Safety Evaluation

cc w/enclosure:
See next page

Distribution:
Docket File JStevens, LB1
NRC & L PDRs GZwetzig, RV
Gray and Reading Files
OELD
ACRS 10
HThompson
EButcher
PKreutzer
LLazo
BGrimes
EJordan

ORB#3:DL
PKreutzer
7/10/85

ORB#3:DL
LLazo;ef
7/10/85

ORB#3:DL
EButcher
7/11/85

8507230041 850711
PDR ADOCK 05000344
P PDR

Mr. Bart D. Withers
Portland General Electric Company

Trojan Nuclear Plant

cc:
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Trojan Nuclear Plant
Post Office Box 0
Rainier, Oregon 97048

Robert M. Hunt, Chairman
Board of County Commissioners
Columbia County
St. Helens, Oregon 97501

William T. Dixon
Oregon Department of Energy
Labor and Industries Building
Room 111
Salem, Oregon 97310

Regional Administrator, Region V
U.S. Nuclear Regulatory Commission
Office of Executive Director for Operations
1450 Maria Lane, Suite 210
Walnut Creek, California 94596