



NIAGARA MOHAWK POWER CORPORATION / 300 ERIE BOULEVARD WEST, SYRACUSE, N.Y. 13202 / TELEPHONE (315) 474-1511

August 23, 1985
(NMP2L 0475)


Mr. R. W. Starostecki, Director
U.S. Nuclear Regulatory Commission
Region I
Division of Reactor Projects
631 Park Avenue
King of Prussia, PA 19406

Re: Nine Mile Point - Unit 2
Docket No. 50-410

Dear Mr. Starostecki:

Enclosed is an interim report in accordance with 10CFR50.55(e) for the problem concerning acceptance of soldering installations that are rejectable. This problem was reported via tel-con to R. A. Gramm of your staff on July 24, 1985.

Very truly yours,


C. V. Mangan
Senior Vice President

CVM/GG/c1a
(1206H)

Enclosure

xc: Director of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

R. A. Gramm, NRC Senior Resident Inspector

Project File

8509260007 850823
PDR ADOCK 05000410
S PDR

1/1 12 27

NIAGARA MOHAWK POWER CORPORATION
NINE MILE POINT - UNIT 2
DOCKET NO. 50-410

Interim Report for a Problem Concerning
Acceptance of Soldering Installations That are Rejectable.
(55(e)85-24)

Description of the Problem

A reinspection of the soldered connections on 32 switches installed in the reactor water cleanup and recirculation control board, Panel 2CEC*PNL602, identified several nonconforming soldered connections that were found to be documented as satisfactory when initially inspected. The subject connections were found to be unsatisfactory based on the acceptance criteria established in the Quality Assurance Inspection Plan for Specification No. E062A.

This matter is still under investigation, and a final report will be submitted by September 30, 1985.