

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Callaway Plant Unit 1										DOCKET NUMBER (2) 0 5 0 0 0 4 8 3				PAGE (3) 1 OF 0 4									
TITLE (4) Technical Specification Violation																							
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)													
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES				DOCKET NUMBER(S)										
0	5	2	9	8	5	8	5	0	2	8	0	0	0	7	1	1	8	5	0	5	0	0	0
OPERATING MODE (9)		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)																					
1		20.402(b)				20.405(c)				50.73(a)(2)(iv)				73.71(b)									
POWER LEVEL (10)		20.406(a)(1)(i)				50.36(c)(1)				50.73(a)(2)(v)				73.71(c)									
1 1 0 0		20.406(a)(1)(ii)				50.36(c)(2)				50.73(a)(2)(vii)				OTHER (Specify in Abstract below and in Text, NRC Form 365A)									
		20.406(a)(1)(iii)				50.73(a)(2)(i)				50.73(a)(2)(viii)(A)													
		20.406(a)(1)(iv)				50.73(a)(2)(ii)				50.73(a)(2)(viii)(B)													
		20.406(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(ix)													
LICENSEE CONTACT FOR THIS LER (12)																							
NAME Charles D. Naslund, Superintendent I&C										TELEPHONE NUMBER													
										AREA CODE 3 1 4 6 7 6 - 8 5 0 0													
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																							
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC		CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC													
SUPPLEMENTAL REPORT EXPECTED (14)												EXPECTED SUBMISSION DATE (15)		MONTH	DAY	YEAR							
YES (If yes, complete EXPECTED SUBMISSION DATE)												X		NO									

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On 6/11/85 at 0150 CDT, while in Mode 1 (Power Operation) at 99% power, it was discovered during an inspection of the Unit Vent Wide Range Gas Monitor GT-RE-21B that a sample line had been disconnected from the suction of the sample pump for maintenance activities on 5/29/85 and was not reconnected due to a personnel error. The sample line was reconnected promptly upon discovery.

On 6/7/85 at 2238 a Reactor Trip occurred. Per Technical Specification (T/S) 3.11.2.1 grab samples of Unit Vent gaseous concentration were taken using GT-RE-21B as the sampling monitor. Since the sample line had been disconnected on 5/29/85 and reconnected on 6/11/85, the grab samples taken from 6/7/85 to 6/11/85 are invalid. In addition, T/S 3.3.3.6.c and T/S 3.3.3.10.b were violated since the actions required during the inoperability of GT-RE-21B were never taken between 5/29/85 and 6/11/85.

To prevent recurrence, I&C technicians have been reinstructed to review steps taken during maintenance activities to ensure equipment is returned to its normal configuration.

Effluent accountability was not compromised during the inoperability of GT-RE-21B. Routine sampling of the Unit Vent is performed using Unit Vent Particulate and Iodine Monitor GT-RE-21A. These samples are taken in accordance with T/S 3.11.2.1 and had been used to ensure that limits required by Technical Specifications were not exceeded. At no time was the public health or safety compromised.

8507230270 850711
PDR ADDOCK 05000483
S PDR

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMB NO. 3150-0104

EXPIRES: 8/31/85

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
Callaway Plant Unit 1	05000483	85	028	00	02	OF	04

TEXT (If more space is required, use additional NRC Form 366A's) (17)

At 1337 CDT on 5/29/85 Unit Vent Wide Range Gas Monitor GT-RE-21B (IEEE Standard 805-1983 System - VL, IEEE Standard 803A-1983 Component - MON) was declared inoperable due to an internal flow control valve problem on the monitor's low range pump. A faulty diaphragm was replaced on the pump and the monitor was declared operable at 1739 that same day.

At 2238 on 6/7/85 a Reactor Trip occurred due to a high negative flux rate trip (refer to LER 85-026-00 dated 6/28/85). In accordance with Technical Specification (T/S) 3.11.2.1, Table 4.11-2, Footnote 3, "Sampling and analysis shall also be performed following shutdown, startup, or a THERMAL POWER change exceeding 15% of RATED THERMAL POWER within 1 hour period", a grab sample of Unit Vent gaseous concentration was taken using a portable sampling cart. In addition, Footnote 7 of the same T/S requires "...for unit vent, sampling shall also be performed at least once per 24 hours for at least 7 days following each shutdown, STARTUP or THERMAL POWER change exceeding 15% of RATED THERMAL POWER within a 1-hour period..." Samples were taken from 6/7/85 to 6/15/85 using GT-RE-21B as the sampling monitor.

At 0150 on 6/11/85 it was discovered during an inspection of the monitor that a sample line on GT-RE-21B had been disconnected from the suction of the sample pump (refer to Figure 1). It was later determined that this sample line had been disconnected for the maintenance activities on 5/29/85, as described above, and was not reconnected due to a personnel error. The sample line was reconnected promptly upon discovery. The plant was in Mode 1 (Power Operation) at 99% power upon discovery of the event.

During the period from 6/7/85 (Reactor Trip) to 6/15/85 GT-RE-21B was used to obtain the samples required by T/S 3.11.2.1. The sample required by T/S 3.11.2.1, Table 4.11-2, Footnote 3 was taken using a portable sampling cart which was tapped into the sample line as shown in Figure 1. The portable sampling cart is equipped with its own pump which was used to obtain this sample of Unit Vent gaseous concentration, thus this sample is valid. The samples required by Table 4.11-2, Footnote 7 were taken with the pump on GT-RE-21B for 4 days prior to the discovery of the disconnected sample line on 6/11/85 and are thus considered invalid. The remaining 3 samples required by Footnote 7 were taken after the sample line was reconnected to the pump and are valid. GT-RE-21B was not used for any other sampling activities during the period from 5/29/85 to 6/11/85.

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMB NO. 3150-0104
EXPIRES: 8/31/85

FACILITY NAME (1) Callaway Plant Unit 1	DOCKET NUMBER (2) 0 5 0 0 0 4 8 3	LER NUMBER (6)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
		8 5	— 0 2 8	— 0 0	0 3	OF	0 4

TEXT (If more space is required, use additional NRC Form 366A's) (17)

Also as a result of this monitor's inoperability from 5/29/85 to 6/11/85, two additional Technical Specifications were violated. T/S 3.3.3.6.c requires that "With the number of OPERABLE channels for the containment radiation level monitor or the unit vent - high range noble gas monitor less than the Minimum Channels OPERABLE requirements of Table 3.3-10, initiate the preplanned alternate method of monitoring the appropriate parameter(s) within 72 hours and either restore the inoperable channel to OPERABLE status within 7 days, or prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within 14 days..." The preplanned alternate method of monitoring the appropriate parameter(s) was not initiated within 72 hours, thus violating the first part of this ACTION. However, OPERABILITY was restored immediately upon discovery of the disconnected sample line, thereby satisfying the second part of this ACTION. Furthermore, T/S 3.3.3.10.b, Table 3.3-13, Action 40 states, "With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue for up to 30 days provided grab samples are taken at least once per 12 hours and these samples are analyzed for radioactivity within 24 hours." Grab samples were not taken during the inoperability of GT-RE-21B thus violating this T/S.

To prevent recurrence of personnel errors that disable equipment, I&C technicians have been reinstructed to review steps taken during maintenance activities. This review at the conclusion of the maintenance activity will be made to ensure equipment is returned to its normal configuration. This incident has also been reviewed with Health Physics technicians; the need to be observant of abnormal operating conditions associated with the Wide Range Gas Monitor was emphasized.

Despite the inoperability of GT-RE-21B, effluent accountability was not compromised. Routine sampling of the Unit Vent is performed using sampling points associated with the Unit Vent Particulate and Iodine Monitor GT-RE-21A (IEEE Standard 805-1983 System - VL, IEEE Standard 803A-1983 Component - MON) in accordance with approved procedures. These samples, performed in accordance with T/S 3.11.2.1, were utilized, as described in the OFFSITE DOSE CALCULATION MANUAL, to ensure that the gaseous effluent release limits of T/S 3.11.2.2 and 3.11.2.3 were not exceeded. In no way has this incident affected the health or safety of the public.

Previous occurrences: None.

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

U.S. NUCLEAR REGULATORY COMMISSION
APPROVED ONS NO 3150-0104
EXPIRES 8/31/86

FACILITY NAME (1)

Callaway Plant Unit 1

DOCKET NUMBER (2)

050004813815-0218-0004 OF 04

LER NUMBER (6)

YEAR SEQUENTIAL REVISION
NUMBER NUMBER NUMBER

PAGE (3)

TEXT (If more space is required, use additional NRC Form 2554 (2/11/77))

P - PUMP
F - FILTER




FIGURE 1: SCHEMATIC OF UNIT VENT WIDE RANGE GAS MONITOR GT-RE-21B

UNION ELECTRIC COMPANY
1901 GRATIOT STREET-ST. LOUIS

MAILING ADDRESS:
P.O. BOX 149
ST. LOUIS, MO. 63166

July 11, 1985

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

ULNRC-1136

Gentlemen:

DOCKET NUMBER 50-483
CALLAWAY PLANT UNIT 1
FACILITY OPERATING LICENSE NPF-30
LICENSEE EVENT REPORT 85-028-00
TECHNICAL SPECIFICATION VIOLATION

The enclosed Licensee Event Report is submitted pursuant to 10 CFR
50.73(a)(2)(i) concerning the inoperability of the Unit Vent Wide Range
Gas Monitor.

Andrew P. Neuhalter
S. E. Miltenberger
for Manager, Callaway Plant

CDN/WRR/JMK/gjt
Enclosure

cc: Distribution attached

1522
1/1

cc distribution for ULNRC-1136

Mr. James G. Keppler
Regional Administrator
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

American Nuclear Insurers
c/o Dottie Sherman, Library
The Exchange Suite 245
270 Farmington Avenue
Farmington, CT 06032

Records Center
Institute of Nuclear Power Operations
Suite 1500
1100 Circle 75 Parkway
Atlanta, GA 30339

Mr. Nicholas A. Petrick
Executive Director, SNUPPS
5 Choke Cherry Road
Rockville, Maryland 20850

Mr. J. H. Smith
Bechtel Power Corporation
SNUPPS Project
15740 Shady Grove Road
Gaithersburg, Maryland 20877-1454

NRC Resident Inspector
D. F. Schnell
J. F. McLaughlin
J. E. Davis (Z40LER)
D. W. Capone/R. P. Wendling
F. D. Field
R. L. Powers
A. C. Passwater/D. E. Shafer/D. J. Walker
G. A. Hughes
W. R. Robinson (QA Record)
J. M. Price
C. D. Naslund
J. R. Peevy
R. A. McAleenan
L. K. Robertson (470) (NSRB)
Merlin Williams, Wolf Creek
SEM Chrono
3456-0021.6
3456-0260
Z40ULNRC
G56.37
N. Date