

Commonwealth Edison Company
LaSalle Generating Station
2601 North 21st Road
Marseilles, IL 61341-9757
Tel 815-357-6761



December 9, 1996

**United States Nuclear Regulatory Commission
Washington, D.C. 20555**

Attention: Document Control Desk


Subject: LaSalle County Station Units 1 and 2
Monthly Performance Report
NRC Docket Numbers 50-373 and 50-374.

Enclosed is the LaSalle County Station Monthly Performance Report for the month of November, 1996.

The Summary of Operations section in the September Monthly Performance Report for Unit 2 stated that "the unit started the month in a coastdown condition for the upcoming refuel outage." The following clarification replaces this statement:

At the beginning of the reporting period, the plant was derated due to suppression of a fuel leak. This limited the unit to ninety percent power. Additionally, the number two Turbine Control Valve had been administratively closed in August and remained closed during the September reporting period. These two factors limited the reactor power to eighty percent. On September 21, 1996, the unit shutdown for a scheduled refueling outage.

Respectfully,


D. J. Ray
Station Manager
LaSalle County Station

Enclosure

9612170134 961209
PDR ADOCK 05000373
R PDR

11
124

cc: A. B. Beach, NRC Region III Administrator
M. P. Huber, NRC Senior Resident Inspector - LaSalle
M. L. Dapas, NRC Region III Branch Chief
D. M. Skay, Project Manager, NRR - LaSalle
C. H. Mathews, IDNS Resident Inspector - LaSalle
D. Deppa, IDNS Reactor Safety - Springfield
P. Doverspike, GE Representative - LaSalle
D. L. Farrar, Nuclear Regulatory Services Manager
INPO - Records Center
DCD - Licensing (Hardcopy: Electronic:)
Central file