

LASALLE NUCLEAR POWER STATION

UNIT 1 AND UNIT 2

MONTHLY PERFORMANCE REPORT

COMMONWEALTH EDISON COMPANY

NRC DOCKET NO. 050-373

NRC DOCKET NO. 050-374

LICENSE NO. NPF-11

LICENSE NO. NPF-18

TABLE OF CONTENTS

- I. Monthly Report for LaSalle Unit One
 - A. Summary of Operations Experience
 - B. Operating Data Report
 - C. Average Daily Power Level
 - D. Unit Shutdowns and Power Reductions
 - E. Unique Reporting Requirements
- II. Monthly Report for LaSalle Unit Two
 - A. Summary of Operations Experience
 - B. Operating Data Report
 - C. Average Daily Power Level
 - D. Unit Shutdowns and Power Reductions
 - E. Unique Reporting Requirements

I. Monthly Report for LaSalle Unit One--November, 1996

A. SUMMARY OF OPERATING EXPERIENCE FOR UNIT ONE

DAY	TIME	EVENT
1	0000	Reactor subcritical, generator off-line. Maintenance outage in progress.
30	2400	Reactor subcritical, generator off-line. Maintenance outage in progress.

B. OPERATING DATA REPORT FOR UNIT ONE

DOCKET NO.: 050-373
UNIT: LaSalle One
DATE: 12/07/96
COMPLETED BY: L. Calfa
TELEPHONE: (815)357-6761 x2620

OPERATING STATUS

1. Reporting Period: November, 1996 Gross Hours: 720
2. Currently Authorized Power Level: 3,323 (MWt)
Design Electrical Rating: 1,078 (MWe-net)
Max Dependable Capacity: 1,036 (MWe-net)
3. Power Level To Which Restricted (If Any): None
4. Reasons For Restriction (If Any): N/A

		THIS MONTH	YEAR-TO-DATE	CUMULATIVE
5.	Reactor Critical Hours	0.0	3,799.9	78,741.9
6.	Reactor Reserve Shutdown Hours	0.0	0.0	1,641.2
7.	Hours Generator On-Line	0.0	3,496.5	76,838.0
8.	Unit Reserve Shutdown Hours	0.0	0.0	1.0
9.	Gross Thermal Energy (MWHt)	0.0	10,234,948	228,599,589
10.	Gross Electric Energy (MWHe)	0.0	3,406,602	76,450,484
11.	Net Electrical Energy (MWHe)	0.0	3,300,358	73,669,454
12.	Reactor Service Factor (%)	0.0	47.3	69.5
13.	Reactor Availability Factor (%)	0.0	47.3	71.0
14.	Unit Service Factor (%)	0.0	43.5	67.8
15.	Unit Availability Factor	0.0	43.5	67.8
16.	Unit Capacity Factor (MDC)	0.0	39.6	62.8
17.	Unit Capacity Factor (design MWe)	0.0	38.1	60.3
18.	Unit Forced Outage Factor (%)	0.0	29.1	9.2

19. Shutdowns Scheduled Over Next 6 Months: Forced Outage: 09/22/96-11/28/96
Planned Maintenance Outage: 11/29/96
20. If Shutdown at End of Report Period, Estimated Date of Startup: 1/15/97

C. AVERAGE DAILY UNIT POWER LEVEL (MWe-Net) FOR UNIT ONE

DOCKET NO.: 050-373
UNIT: LaSalle One
DATE: 12/07/96
COMPLETED BY: L. Calfa
TELEPHONE: (815)357-6761 x2620

MONTH: November, 1996:

DAY	POWER	DAY	POWER
1	0	17	0
2	0	18	0
3	0	19	0
4	0	20	0
5	0	21	0
6	0	22	0
7	0	23	0
8	0	24	0
9	0	25	0
10	0	26	0
11	0	27	0
12	0	28	0
13	0	29	0
14	0	30	0
15	0		
16	0		

D. UNIT SHUTDOWNS AND POWER REDUCTIONS >20% FOR UNIT ONE

YEARLY SEQUENTIAL NUMBER	DATE (YY/MM/DD)	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON CODE	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER	CORRECTIVE ACTIONS OR COMMENTS
05	96/11/29	S	720	B	2	Maintenance outage due to engineering concerns.

Summary of Operation:

The unit remained shutdown for the entire month. On October 29, 1996 the forced outage status was changed to a planned maintenance outage. A management decision was made to keep the unit shutdown to address a number of engineering concerns.

C. AVERAGE DAILY UNIT POWER LEVEL (MWe-Net) FOR UNIT TWO

DOCKET NO.: 050-374
UNIT: LaSalle Two
DATE: 12/07/96
COMPLETED BY: L. Calfa
TELEPHONE: (815)357-6761 x2620

MONTH: November, 1996:

DAY	POWER	DAY	POWER
1	0	17	0
2	0	18	0
3	0	19	0
4	0	20	0
5	0	21	0
6	0	22	0
7	0	23	0
8	0	24	0
9	0	25	0
10	0	26	0
11	0	27	0
12	0	28	0
13	0	29	0
14	0	30	0
15	0		
16	0		

E. UNIQUE REPORTING REQUIREMENTS FOR UNIT TWO

1. Challenges to Safety/Relief Valve Operations--None
2. Major Changes to Radioactive Waste Treatment Systems--None
3. Off-Site Dose Calculation Manual Changes--None

E. UNIQUE REPORTING REQUIREMENTS FOR UNIT ONE

1. Challenges to Safety/Relief Valve Operations--None
2. Major Changes to Radioactive Waste Treatment System--None
3. Off-Site Dose Calculation Manual Changes--None

II. Monthly Report for LaSalle Unit Two--November, 1996

A. SUMMARY OF OPERATING EXPERIENCE FOR UNIT TWO

DAY	TIME	EVENT
1	0000	Reactor subcritical, generator off-line. Refuel outage, L2R07, in progress.
30	2400	Reactor subcritical, generator off-line. Refuel outage, L2R07, in progress.

D. UNIT SHUTDOWNS AND POWER REDUCTIONS >20% FOR UNIT TWO

YEARLY SEQUENTIAL NUMBER	DATE (YY/MM/DD)	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON CODE	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER	CORRECTIVE ACTIONS OR COMMENTS
06	96/09/22	S	720	C	2	Refuel Outage (L2R07)

Summary of Operation:

The unit was in a scheduled refuel outage the entire month.