

## B. OPERATING DATA REPORT FOR UNIT TWO

DOCKET NO.: 050-374  
 UNIT: LaSalle Two  
 DATE: 12/07/96  
 COMPLETED BY: L. Calfa  
 TELEPHONE: (815)357-6761 x2620

### OPERATING STATUS

1. Reporting Period: October, 1996 Gross Hours: 720
2. Currently Authorized Power Level: 3,323 (MWt)  
 Design Electrical Rating: 1,078 (MWe-net)  
 Max Dependable Capacity: 1,036 (MWe-net)
3. Power Level To Which Restricted (If Any): None
4. Reasons For Restriction (If Any): N/A

		THIS MONTH	YEAR-TO-DATE	CUMULATIVE
5.	Reactor Critical Hours	0.0	5,738.8	77,028.4
6.	Reactor Reserve Shutdown Hours	0.0	0.0	1,716.9
7.	Hours Generator On-Line	0.0	5,644.0	75,970.2
8.	Unit Reserve Shutdown Hours	0.0	0.0	0.0
9.	Gross Thermal Energy (MWHt)	0.0	17,128,001	230,522,687
10.	Gross Electric Energy (MWe)	0.0	5,824,691	77,175,924
11.	Net Electrical Energy (MWe)	0.0	5,642,329	73,973,643
12.	Reactor Service Factor (%)	0.0	71.4	72.5
13.	Reactor Availability Factor (%)	0.0	71.4	74.1
14.	Unit Service Factor (%)	0.0	70.2	71.5
15.	Unit Availability Factor	0.0	70.2	71.5
16.	Unit Capacity Factor (MDC)	0.0	67.7	67.2
17.	Unit Capacity Factor (design MWe)	0.0	65.1	64.6
18.	Unit Forced Outage Factor (%)	0.0	10.6	9.1

19. Shutdowns Scheduled Over Next 6 Months: Refuel, 09/20/96, 12 weeks
20. If Shutdown at End of Report Period, Estimated Date of Startup: 1/16/97