

FCMLB:JD
030-17488
(03407)

AUG 22 1980

Pharmaco Nuclear, Inc.
ATTN: William H. McHugh, Ph.D.
Radiation Safety Officer
100 North Euclid Avenue
Suite 900
St. Louis, MO 63108

Gentlemen:

Enclosed is the distribution license that you requested by application dated April 7, 1980.

Your license contains a special condition that states: The licensee's ventilation system shall be measured at quarterly intervals to assure that system performance meets the specifications submitted in letter dated July 28, 1980.

In accordance with License Condition No. 23, you may not obtain xenon-133 or liquid iodine-131 until you:

- a. Modify the ventilation system as specified in your letter of July 23, 1980.
- b. Make confirmatory measurements to assure that the modified ventilation system performs according to the specifications in your letter of July 23, 1980.

Please review your license carefully to ensure that you are in compliance with all of the terms and conditions contained therein.

Sincerely,

Joseph DelMedico
Material Licensing Branch
Division of Fuel Cycle and
Material Safety

CRESS
Delmedico 1/L
8/20/80

FCMLB *JD*
JDelMedico:en
8/21/80

8009160138

A8