

SOUTH CAROLINA ELECTRIC & GAS COMPANY

POST OFFICE 764

COLUMBIA, SOUTH CAROLINA 29218

O. W. DIXON, JR.
VICE PRESIDENT
NUCLEAR OPERATIONS

85 SEP 17 11:14 AM
September 16, 1985

Dr. J. Nelson Grace
Regional Administrator
U.S. Nuclear Regulatory Commission
Suite 2900
101 Marietta Street, NW
Atlanta, Georgia 30323


SUBJECT: Virgil C. Summer Nuclear Station
Docket No. 50/395
Operating License No. NPF-12
Special Report (SPR 85-013)

Dear Dr. Grace:

Attached is a Special Report for the Virgil C. Summer Nuclear Station. This Special Report is submitted pursuant to the requirements of Technical Specification 3.3.3.4 and 6.9.2.

Should there be any questions, please call us at your convenience.

Very truly yours,



O. W. Dixon, Jr.

RMF:OWD/lcd
Attachment

cc: V. C. Summer
J. A. Warren
T. C. Nichols, Jr./O. W. Dixon, Jr.
E. H. Crews, Jr.
E. C. Roberts
W. A. Williams, Jr.
D. A. Nauman
Group Managers
O. S. Bradham
C. A. Price
S. R. Hunt
J. F. Heilman
C. L. Ligon (NSRC)

K. E. Nodland
R. A. Stough
G. Percival
C. W. Hehl
J. B. Knotts, Jr.
S. D. Hogge
W. R. Baehr
I&E Washington
Document Management
Branch
INPO Records Center
ANI Library
NPCF
File

8509260271 850916
PDR ADOCK 05000395
S PDR

11
IE19

Dr. J. Nelson Grace
SPR 85-013
Page Two
September 16, 1985

EVENT DESCRIPTION

On August 30, 1985 at 1930 hours, a loss of indication on meteorological instrumentation was identified by operators in the main control room. The inoperability of the meteorological instrumentation was apparently due to a lightning strike on the meteorological instrumentation tower. The instrumentation affected included the power supply to the signal translator for wind speed and direction, the ten meter wind speed instrument, the forty meter temperature instrument, the ten and sixty one meter wind direction instruments, and the wind direction recorder.

CORRECTIVE ACTION

All instrumentation was repaired and returned to service on September 9, 1985 at 1500 hours. No further corrective action is planned by the Licensee.