



Omaha Public Power District

444 South 16th Street Mall
Omaha NE 68102-2247

December 5, 1996
LIC-96-0194

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, DC 20555

Reference: Docket No. 50-285

SUBJECT: Steam Generator Tube Plugging Report

The Omaha Public Power District (OPPD) completed eddy-current testing of the steam generator tubes at Fort Calhoun Station (FCS) on November 8, 1996, during the Sixteenth Refueling Outage. As a result of this testing and in accordance with Technical Specification 3.17(5)(i), OPPD reports that thirty-six (36) tubes were plugged in Steam Generator A, and twenty-one (21) tubes were plugged in Steam Generator B. To date, Steam Generator A has 92 plugged tubes and Steam Generator B has 76 plugged tubes. Specific details in regard to steam generator tube plugging will be provided in the six (6) month report required by Technical Specification 3.17(5)(ii).

If you should have any questions, please contact me.

Sincerely,

T. L. Patterson
T. L. Patterson
Division Manager
Nuclear Operations

TLP/mle

c: Winston & Strawn
L. J. Callan, NRC Regional Administrator, Region IV
L. R. Wharton, NRC Project Manager
W. C. Walker, NRC Senior Resident Inspector

170106

9612170454 961205
PDR ADOCK 05000285
P PDR