

607

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

COMMISSIONERS:

Nunzio J. Palladino, Chairman
Thomas M. Roberts
James K. Asselstine
Frederick M. Bernthal
Lando W. Zech, Jr.

'85 SEP 24 P3:52

OFFICE OF
DOCKETING & SERVICE
BRANCH

SEP 24 1985

In the Matter of

LONG ISLAND LIGHTING COMPANY

(Shoreham Nuclear Power Station)

Docket No. 50-322-OL-4

ORDER

In ALAB-800, the Appeal Board decided that 10 C.F.R. Part 73 requires Long Island Lighting Company (LILCO) to treat its alternate AC system as vital equipment if LILCO intended to rely on that system for AC power during low power testing. We decided on June 11, 1985 to affirm ALAB-800 insofar as it held that part of the system should be treated as vital. However, in light of the issuance of a license based on the adequacy of the main Shoreham AC system, we have decided to defer indefinitely the issuance of an opinion explaining our June 11 decision.

It is so ORDERED.

For the Commission



SAMUEL J. CHILK
Secretary of the Commission



Dated at Washington, D.C.

this 7th day of September, 1985

8509260358 850924
PDR ADOCK 05000322
G PDR

DS02