



## State of New Jersey

Christine Todd Whitman  
Governor

Department of Environmental Protection

Robert C. Shinn, Jr.  
Commissioner

Division of Environmental Safety, Health  
and Analytical Programs  
Radiation Protection Programs  
Bureau of Nuclear Engineering  
CN 415

Trenton, New Jersey 08625-0415

Tel (609) 984-7700

Fax (609) 984-7513

November 25, 1996

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Gentlemen:

Subject: Oyster Creek Generating Station  
Docket No. 50-219  
Amendment to Facility Operating License  
Technical Specification Change Request 243


The subject request was submitted to the NRC by GPU Nuclear letter dated October 10, 1996. The proposed amendment changes the Trip Setting for Technical Specification Table 3.1.1 Item No. G.3, Automatic Depressurization System (ADS) by clarification of the functional requirement to provide an interlock permissive which ensures that a source of cooling water is available via the Core Spray System prior to depressurization.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering (BNE) has reviewed the request in accordance with the requirements of 10 CFR 50.91(b) and has no comments.

9612180039 961125  
PDR ADOCK 05000219  
P PDR

If you have any questions, please contact Rich Pinney at (609) 984-7558.

Sincerely,

A handwritten signature in dark ink, appearing to read "Kent W. Tosch", with a long horizontal flourish extending to the right.

Kent W. Tosch, Manager  
Bureau of Nuclear Engineering

c: Distribution

Distribution

Jill Lipoti  
N.J. DEP

Dennis Zannoni  
N.J. DEP

D. Chawaga  
NRC Region I State Liaison Officer

L. Briggs  
NRC Sr. Resident Inspector

R. Eaton  
NRC Project Manager

G. Busch  
GPU Nuclear