

CATAWBA NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

October 1996

1. Personnel Exposure -

The total station liquid release for October has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for October has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

## UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-413  
 UNIT NAME CATAWBA 1  
 DATE 11/15/96  
 COMPLETED BY R. A. Williams  
 TELEPHONE (704)-382-5346

\* REVISION 1  
 PAGE 2 OF 2

REPORT MONTH October 1996

N O .	DATE	(1) T Y P E	DURATION HOURS	(2) R E A S O N	(3) M E T H O D O F S H U T D O W N R/X	LICENSE EVENT REPORT NO.	(4) S Y S T E M C O D E	(5) C O M P O N E N T C O D E	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
13-P	96-10- 8	S	--	B	--		HA	TRANSF	UNIT LOAD TRANSIENT TEST
14-P	96-10- 9	F	--	A	--		HA	GENERA	GENERATOR COOLING SYSTEM TEMPERATURE PROBLEMS
15-P	96-10-27	F	--	A	--		EA	TRANSF	"1A" MAIN TRANSFORMER COOLING PROBLEM
16-P	96-10-28	F	--	A	--		HA	CKTBKR	GENERATOR BREAKER "1AT" MOTOR OPERATED DISCONNECT CLOSURE PROBLEM
17-P	96-10-29	F	--	B	--		EA	TRANSF	"1A" MAIN TRANSFORMER MAINTENANCE

(1)  
 F Forced  
 S Scheduled

(2)  
 Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance or test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Examination  
 F-Administrative  
 G-Operator Error (Explain)  
 H-Other (Explain)

(3)  
 Method:  
 1-Manual  
 2-Manual Scram  
 3-Automatic Scram  
 4-Other (Explain)

(4)  
 Exhibit C - Instructions  
 for Preparation of Data  
 Entry Sheets For Licensee  
 Event Report (LER)  
 File (NUREG-0161)

(5)  
 Exhibit I - Same Source