

POINT BEACH NUCLEAR PLANT
UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH OCTOBER - 1996

Docket No. 50-301
Unit Name Point Beach, Unit 2
Date 12/5/96
Completed By B. J. Vander Velde
Telephone No. 414/755-6681

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Reactor Shut Down ³	Licensee Event Report No.	System Code ⁴	Component Code ⁵	Cause and Corrective Action To Prevent Recurrence
4	961005	S	720.0	C	1	NA	NA	NA	Scheduled refueling and maintenance (U2R22). Major work items include: Replacing both Unit 2 steam generators; main control board wire separation resolution; replace 8 main steam condenser valves; HP turbine crossunder piping; repair service water west header; replace boric acid and reactor makeup water totalizers; replace safety injection accumulator level transmitters; modify X02, X03, and X04 transformer metering and relay circuits; and exciter modification.

¹F: Forced
S: Scheduled

²Reason:
A - Equipment Failure (explain)
B - Maintenance or Testing
C - Refueling
D - Regulatory Restriction
E - Operator Training &
Licensing Exam
F - Administrative
G - Operational Error (explain)
H - Other (explain)

³Method:
1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Continuation of
Previous Shutdown
5 - Reduced Load
6 - Other (explain)

⁴Exhibit G - Instructions
for preparation of
data entry sheets
LER file (NUREG-0161)

⁵Exhibit I - Same Source