

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Otto L. Maynard
Chief Administrative Officer

December 10, 1996

CO 96-0097


U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555

Subject: Docket No. 50-482: November, 1996, Monthly
Operating Report

Gentlemen:

Attached to this letter is the November, 1996, Monthly Operating Report for Wolf Creek Generating Station. This submittal is being made in accordance with the requirements of Technical Specification 6.9.1.8.

Very truly yours,



Otto L. Maynard

OLM/jad

Attachment

cc: L. J. Callan (NRC), w/a
W. D. Johnson (NRC), w/a
J. F. Ringwald (NRC), w/a
J. C. Stone (NRC), w/a

9612180121 961130
PDR ADOCK 05000482
R PDR

11
1224

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

MONTHLY OPERATING REPORT

MONTH: November YEAR: 1996

Docket No.: 50-482

Facility Operating License No.: NPF-42

Report No. 141

SUMMARY

The following report highlights the operating experience of Wolf Creek Generating Station for the month of November, 1996. This report is being provided pursuant to Technical Specification 6.9.1.8.

I. SUMMARY OF OPERATING EXPERIENCE

The unit operated at or near 100% power, Mode 1, November 1, 1996, through November 30, 1996.

II. MAJOR SAFETY RELATED MAINTENANCE ACTIVITIES

None

OPERATING DATA REPORT
DOCKET NO. 50-482
WOLF CREEK GENERATING STATION
WOLF CREEK NUCLEAR OPERATING CORPORATION
DATE 12-04-96
TELEPHONE 316-364-8831

OPERATING STATUS

1. Reporting Period: November, 1996 Gross Hours in Reporting Period: 720
 2. Currently Authorized Power Level (Mwt): 3565 Max. Depend. Capacity (MWe-Net): 1163
Design Electrical Rating (MWe-Net): 1170
 3. Power Level to Which Restricted (If Any) (MWe-Net): N/A
 4. Reasons for Restriction (If Any): N/A
- | | This Month | Yr. to Date | Cumulative |
|---|------------------|-------------------|--------------------|
| 5. Number of Hours Reactor was Critical | <u>720.0</u> | <u>6,391.2</u> | <u>81,007.9</u> |
| 6. Reactor Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>339.8</u> |
| 7. Hours Generator on Line | <u>720.0</u> | <u>6,336.2</u> | <u>80,115.9</u> |
| 8. Unit Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>0.0</u> |
| 9. Gross Thermal Energy Generated (MWh) | <u>2,564,301</u> | <u>22,235,033</u> | <u>267,576,703</u> |
| 10. Gross Electrical Energy Generated (MWh) | <u>890,923</u> | <u>7,668,705</u> | <u>92,927,625</u> |
| 11. Net Electrical Energy Generated (MWh) | <u>856,170</u> | <u>7,319,018</u> | <u>88,755,869</u> |
| 12. Reactor Service Factor | <u>100.0%</u> | <u>79.5%</u> | <u>82.2%</u> |
| 13. Reactor Availability Factor | <u>100.0%</u> | <u>79.5%</u> | <u>82.5%</u> |
| 14. Unit Service Factor | <u>100.0%</u> | <u>78.8%</u> | <u>81.3%</u> |
| 15. Unit Availability Factor | <u>100.0%</u> | <u>78.8%</u> | <u>81.3%</u> |
| 16. Unit Capacity Factor (Using MDC) | <u>102.2%</u> | <u>78.2%</u> | <u>79.1%</u> |
| 17. Unit Capacity Factor (Using Design MWe) | <u>101.6%</u> | <u>77.8%</u> | <u>77.0%</u> |
| 18. Unit Forced Outage Rate | <u>0.0%</u> | <u>2.5%</u> | <u>4.6%</u> |
19. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of each): None
 20. If Shut Down at End of Report Period, Estimate Date of Startup: N/A

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-482

WOLF CREEK GENERATING STATION

WOLF CREEK NUCLEAR OPERATING CORPORATION

DATE 12-04-96TELEPHONE 316-364-8831MONTH November, 1996DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	1186
2	1187
3	1189
4	1189
5	1188
6	1188
7	1187
8	1187
9	1189
10	1188
11	1189
12	1191
13	1189
14	1189
15	1188
16	1189

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	1189
18	1189
19	1190
20	1190
21	1189
22	1190
23	1191
24	1190
25	1189
26	1190
27	1191
28	1192
29	1191
30	1192
31	N/A

50-482

TATION

RATION

-04-96

4-8831

--	--

- RAM
SCRAM
LOAD

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

UNIT NO. 1

MONTH November, 1996

SUMMARY OF OPERATING EXPERIENCE

Listed below in chronological sequence is a summary of operating experiences for this month which required load reduction or resulted in significant non-load related incidents.

<u>DATE</u>	<u>TIME</u>	<u>EVENT</u>
N/A	N/A	N/A