

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-V-85-62

Date: 09/20/85

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by Region V staff on this date.

FACILITY: Southern California Edison Company  
San Onofre Unit 1  
Docket No. 50-206

Emergency Classification  
☐ Notification of Unusual Event  
☐ Alert  
☐ Site Area Emergency  
☐ General Emergency  
☒ Not Applicable

SUBJECT: REACTOR TRIP INVOLVING INOPERABLE TURBINE-DRIVEN AUXILIARY  
FEEDWATER PUMP AND MAIN TURBINE OVERSPEED

San Onofre Unit 1 tripped at 19:05 on September 19, 1985. A technician adding nitrogen to the "B" auxiliary transformer apparently added it too fast, causing the auxiliary transformer protective devices to trip. This resulted in a turbine trip and reactor trip. A temporary low level was experienced in one steam generator, and the turbine-driven auxiliary feed pump started but tripped after a brief run. The AFP trip was initially believed to be due to overspeed, but inspection during the night indicates the AFP turbine bearings to have been wiped, apparently due to lack of lube oil, and the AFP trip may have resulted from vibration.

Following the main turbine trip, steam reheater dump valves did not actuate as required, resulting in a main turbine overspeed to 126 per cent of normal speed (1800 rpm).

The licensee is still investigating this event. The resident inspectors are examining the licensee's efforts and other circumstances involved in the event.

The licensee will issue a press release this morning.

This information is current as of 8:00 am on September 20, 1985.

CONTACT: P. Johnson  
FTS 463-3745

R. Huey  
(714) 492-2641

DISTRIBUTION

|                    |            |                |           |               |                  |                |
|--------------------|------------|----------------|-----------|---------------|------------------|----------------|
| H St. 12:35        | MNBB 11:32 | Phillips 11:23 | E/W 12:34 | Willste 11:35 | Air Rights 12:36 | Mail:          |
| Chairman Pallidino | EDO        | NRR            | IE        | NMSS          |                  | ADM:DMB        |
| Comm. Zech         | PA         |                | OIA       | RES           |                  | DOT:Trans Only |
| Comm. Bernthal     | MPA        |                | AEOD      |               |                  |                |
| Comm. Roberts      | ELD        |                |           |               |                  |                |
| Comm. Asselstine   |            |                |           |               |                  |                |
| SECY               |            |                |           |               |                  |                |
| ACRS               |            |                |           |               |                  |                |
| CA                 |            |                |           |               |                  |                |
| PDR                |            |                |           |               |                  |                |

Regions: RI-12:38, RII-1:06, RIII-1:07, RIIV-1:08  
INPO 1:31 NSAC 1:10  
Licensee: 3:45  
(Reactor Licensees)  
Resident Inspector 1:32

REGION V: FORM 211  
(Revised 3/14/83)

8509270001 850920  
PDR I&E  
PNO-V-85-062 PDR

IE-34

0/1