



# THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

*Serving The Best Location in the Nation*

MURRAY R. EDELMAN  
VICE PRESIDENT  
NUCLEAR

September 19, 1985

PY-CEI/OIE-0119 L

Mr. C. J. Paperiello, Director  
Division of Reactor Safety  
U.S. Nuclear Regulatory Commission, Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

RE: Perry Nuclear Power Plant  
Docket No. 50-<sup>440</sup>550; 50-441  
Noncompliance 440/85043-01,  
Example (a)

REF: PY-CEI/OIE 0102L--August 20, 1985  
PY-CEI/OIE-0094L--August 9, 1985

Dear Mr. Paperiello:

The purpose of this letter is to advise you of additional information for your files to support closure of Noncompliance 440/85043-01, example (a).

Subsequent to our second response, L. K. Comstock Inspection Report 19141 and L. K. Comstock Nonconformance Report 6443 were initiated to document further review of weld filler metal withdrawal tabs. Nonconformance Report 6443 has been closed based on revision to L. K. Comstock Procedures 4.7.1 and 4.8.18, and acceptable tensile tests of coupons welded with 6013 electrodes. Mr. John Jacobson reviewed corrective actions taken in response to this noncompliance during his inspection conducted from September 10 to 12, 1985. Preliminary results presented at his exit meeting indicate that this item is considered closed.

If there are any questions, please do not hesitate to call.

Sincerely,

*Murray R. Edelman*

Murray R. Edelman  
Vice President  
Nuclear Group

MRE:sab  
Attachment

8509270073 850919  
PDR ADDOCK 05000440  
Q PDR

SEP 23 1985

✓ 801 1/0

Mr. C. J. Paperiello

-2-

September 19, 1985  
PY-CEI/OIE 0119 L

cc: Mr. J. A. Grobe  
USNRC Site, SBB50

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Mr. R. F. Warnick, Chief  
Reactor Projects Branch 1  
Division of Reactor Projects  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137