

K *all* *AH*

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-V-85-48      Date: 07/25/85

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by Region V staff on this date.

FACILITY: Palo Verde Nuclear Generating Station  
Unit 1  
Docket No. 50-528

Emergency Classification  
☐ Notification of Unusual Event  
☐ Alert  
☐ Site Area Emergency  
☐ General Emergency  
☒ Not Applicable

SUBJECT: EXTENDED PLANT OUTAGE

On July 24, 1985, the licensee determined that a plant outage of greater than seven days is expected to repair a main condenser. A broken condenser baffle caused damage to two condenser tubes and the heater drain tank inlet shroud. This was discovered while attempting to identify condenser leakage.

This information is current as of 4:00 p.m. (PDT), July 24, 1985.

CONTACT: R. Zimmerman                      A. Hon  
(602) 386-5260                      FTS 463-3726

DISTRIBUTION

H St. <u>11:14</u>	MNBB <u>10:45</u>	Phillips <u>10:44</u>	E/W <u>10:47</u>	Willste <u>10:48</u>	Air Rights <u>11:15</u>	Mail:
Chairman Pallidino	EDO	NRR	IE	NMSS		ADM:DMB
Comm. Zech	PA		OIA	RES		DOT:Trans Only
Comm. Bernthal	MPA		AEOD			
Comm. Roberts	ELD					
Comm. Asselstine						
SECY						
ACRS						
CA						
PDR						

Regions: RI-12:17, RII-11:34, RIII-12:18, RIV-12:19  
INPO 12:50 NSAC 12:49  
Licensee: \_\_\_\_\_  
(Reactor Licensees)  
Resident Inspector 12:21

REGION V: FORM 211  
(Revised 3/14/83)

8507300326 850725  
PDR I&E  
PNO-V-85-048 PDR

*IE-34 o/i*