



Northeast  
Utilities System

Millstone Offices • Rope Ferry Rd., Waterford, CT

P.O. Box 128  
Waterford, CT 06385-0128  
(203) 447-1791

December 12, 1996

Docket No. 50-245

B16057

Re: 10CFR50.73(a)(2)(iv)

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

This letter forwards Licensee Event Report (LER) 96-056-00, documenting an event that occurred at Millstone Nuclear Power Station, Unit No. 1 on November 12, 1996. This LER is submitted pursuant to 10CFR50.73(a)(2)(iv).

The following is Northeast Nuclear Energy Company's (NNECO's) commitment made within this letter. All other statements made within this letter are for information only.

B16057-1 NNECO commits to revise the surveillance procedure for testing the Diesel Generator Air Compressor Auto Start Logic to appropriately test the air system without causing an inadvertent Diesel Generator start. This will be completed prior to the next scheduled surveillance.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

P. D. Hinnenkamp  
Director, Unit Operations

Attachment: LER 96-056-00

cc: H. J. Miller, Region I Administrator  
T. A. Easlick, Senior Resident Inspector, Millstone Unit No. 1  
J. W. Andersen, NRC Project Manager, Millstone Unit No. 1

9612180394 961212  
PDR ADOCK 05000245  
S PDR

1222  
11