

**Northeast
Utilities System**

Millstone Offices • Rope Ferry Rd., Waterford, CT

P.O. Box 128
Waterford, CT 06385-0128
(203) 447-1791

December 16, 1996

Docket No. 50-245
B16071

Re: 10CFR50.73(a)(2)(i)
10CFR50.73(a)(2)(ii)

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

This letter forwards supplemental Licensee Event Report (LER) 96-020-01, documenting an event that occurred at Millstone Nuclear Power Station, Unit No. 1 on March 22, 1996. This LER is submitted pursuant to 10CFR50.73(a)(2)(i) and 10CFR50.73(a)(2)(ii).

This supplemental report provides the description of the long-term corrective action that was decided upon to be implemented. The Commitment No. B15674-4 has been updated accordingly. This completes the Commitment No. B15674-5.

Also, there are editorial and administrative changes as well as a correction of a typo for a Technical Specification section. Lastly, the Commitments for this LER are moved from the LER form to this letter.

The following are Northeast Nuclear Energy Company's (NNECO's) commitments made within this letter. All other statements made within this letter are for information only.


- B15674-1 NNECO commits to revise design calculations to correctly identify the usable volume of the CST. This will be completed prior to startup for operating cycle 16.
- B15674-2 NNECO commits to perform a review of the calculations of the unusable volume of all safety-related tanks. This review will be completed prior to startup for operating cycle 16.
- B15674-3 NNECO commits to revise administrative procedures to ensure the required volume is available in the CST at all times FWCI is required to be operable, prior to startup for operating cycle 16.

9612190055 961216
PDR ADOCK 05000245
S PDR

B15674-4 NNECO commits to provide procedural guidance, as the long-term corrective action, for maintaining appropriate levels in the CST while the torus is drained. NNECO will complete this prior to shutdown for refueling outage 16.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

A handwritten signature in dark ink, appearing to read 'P. D. Hinnenkamp', is written over a horizontal line.

P. D. Hinnenkamp
Director, Unit Operations

Attachment: LER 96-020-01

cc: Dr. W. D. Travers, Director, Special Projects
H. J. Miller, Region I Administrator
S. Dembek, NRC Project Manager, Millstone Unit No. 1
T. A. Easlick, Senior Resident Inspector, Millstone Unit No. 1