

12-00000
10-00000

U.S. NUCLEAR REGULATORY COMMISSION
LICENSEE EVENT REPORT

APPROVED FOR NRC
3150-0011

CONTROL BLOCK

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 A L J M F 2 00 - 10 0 0 0 0 - 10 0 3 4 1 1 1 1 4 5
LICENSEE CODE 12 13 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 38

01 REPORT SOURCE L 0 5 0 0 0 3 6 4 7 0 4 2 8 8 3 0 5 2 0 8 3 9
DOCKET NUMBER 55 56 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 At 0505 on 4/28/83 during the performance of FNP-2-STP-612.0 (Reactor Coolant
03 Pump Bus Reactor Trip Undervoltage Relay Calibration), 2B reactor coolant pump
04 undervoltage relay 27-3 was declared inoperable due to its out of spec. condition
05 (70.56 volts actual vs. 75.43 volts required). Tech. Spec. 3.3.1, in part, re-
06 quires the relay to be operable. Tech. Spec. 3.3.1 action statement requirements
07 were met. Health/safety of the public was not affected.

08
09
17 LER/RO REPORT NUMBER 8 3
ACTION TAKEN E 16 Z 19
FUTURE ACTION Z 20
EFFECT ON PLANT Z 21
SHUTDOWN METHOD Z 21
HOURS 0 0 0 0
ATTACHMENT SUBMITTED N 23
NPRD-2 FORM SUB N 24
PRIME COMP. SUPPLIER IN 25
COMPONENT MANUFACTURER G I O I E I O
SYSTEM CODE 1 A 11
CAUSE CODE E 12
CAUSE SUBCODE A 13
COMPONENT CODE R E L A Y X 14
COMP. SUBCODE D 15
VALVE SUBCODE Z 16
SEQUENTIAL REPORT NO. 0 1 2 2
OCCURRENCE CODE 0 3
REPORT TYPE L
REVISION NO. 10
26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 This event was attributed to setpoint drift. Following adjustment of the relay
11 setpoint, 2B reactor coolant pump undervoltage relay was declared operable at
12 0515 on 4/28/83.
13
14

15 FACILITY STATUS E 28 1 1 0 0 29 NA OTHER STATUS 30 METHOD OF DISCOVERY B 31 Surveillance Test 32
ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 NA AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
PERSONNEL EXPOSURES NUMBER 0 1 0 0 37 Z 38 NA DESCRIPTION 39
PERSONNEL INJURIES NUMBER 0 1 0 0 40 NA DESCRIPTION 41
LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 NA DESCRIPTION 43
PUBLICITY ISSUED DESCRIPTION 44 NA
20 N 44

8507310223 830520
PDR ADOCK 05000364
S PDR

JEZZ
X

NAME OF PREPARER W. G. Hairston, III

PHONE (205) 899-5156

Alabama Power Company
640 North 18th St
Post Office Box 21
Birmingham, Ala. 35291
Telephone 205 783-6081

F. L. Clayton, Jr.
Senior Vice President
Flintridge Building



Alabama Power

the southern electric system

May 20, 1983

03 MAY 23 AIO: 34

Docket No. 348
Docket No. 364

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, N.W.
Suite 3100
Atlanta, Georgia 30303

Dear Sir:

Joseph M. Farley Nuclear Plant, Unit 1, Licensee Event Report No. LER 83-020/03L-0 and Unit 2, Licensee Event Reports Nos. LER 83-020/03L-0 and LER 83-022/03L-0 are forwarded with three (3) copies of each in accordance with FNP Technical Specification 6.9.1.13 to provide thirty (30) days written notification of the occurrences.

If you have any questions, please advise.

Yours very truly,

F. L. Clayton, Jr.
F. L. Clayton, Jr.

FLCJr/KWM:nac

Enclosures

xc: Director, IE (30 copies)
Director, MIPC (3 copies)

DESIGNATED ORIGINAL
Certified By *[Signature]*

IE22
11
83 RETROFIT