



GULF STATES UTILITIES COMPANY

POST OFFICE BOX 2551 • BEAUMONT, TEXAS 77704

AREA CODE 409 838-6631

September 24, 1985

RBG- 22,163

File No. G9.5

Mr. H. R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Denton:

River Bend Station-Unit 1
Docket No. 50-458

As a result of recent discussions with the NRC Staff, Gulf States Utilities Company has initiated a change to procedure ADM-0053 concerning the Asiatic Clam Control Program. The original procedure was previously submitted for Staff review in a letter dated June 21, 1985.

The change occurs in Section 5.4.1 where the low alarm setpoint for the chlorine analyzer in the Normal Service Water return header will now be 0.5 ppm. The high alarm setpoint will be unspecified. A plant condition report will be initiated if the residual chlorine is not maintained at greater than 0.5 ppm.

Additionally, two minor editorial changes were made in Section 5.5.1 concerning the distribution of clam reports to the appropriate parties in accordance with previous agreements. These procedure changes are available onsite for review.

Should you have any questions on this matter, contact Mr. James Cook at (409) 839-3013.

Sincerely,

J. E. Booker

J. E. Booker
Manager-Engineering,
Nuclear Fuels & Licensing
River Bend Nuclear Group

JEB
JEB/WJR/JWC/kt

8509300121 850924
PDR ADOCK 05000458
P PDR

Cool
1/0