

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) NORTH ANNA POWER STATION, UNIT 1										DOCKET NUMBER (2) 0 5 0 0 0 3 3 8					PAGE (3) 1 OF 0 2	
TITLE (4) MOTOR DRIVEN FIRE PUMP OUT OF SERVICE FOR GREATER THAN SEVEN DAYS																
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)						
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES				DOCKET NUMBER(S)			
0 6	1 3	8 5	8 5	0 0 1	0 0	0 7	1 1	8 5	NORTH ANNA, UNIT 2				0 5 0 0 0 3 3 9			
													0 5 0 0 0 3 3 9			
OPERATING MODE (9)		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)														
1		20.402(b)				20.406(e)				50.73(a)(2)(iv)				73.71(b)		
POWER LEVEL (10)		20.405(a)(1)(i)				50.38(e)(1)				50.73(a)(2)(v)				73.71(e)		
1 0 0		20.405(a)(1)(ii)				50.40(c)(2)				50.73(a)(2)(vi)				X OTHER (Specify in Abstract below and in Text, NRC Form 366A)		
		20.405(a)(1)(iii)				50.73(a)(2)(ii)				50.73(a)(2)(viii)(A)				SPECIAL REPORT		
		20.405(a)(1)(iv)				50.73(a)(2)(iii)				50.73(a)(2)(viii)(B)						
		20.405(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(ix)						
LICENSEE CONTACT FOR THIS LER (12)																
NAME E. WAYNE HARRELL										TELEPHONE NUMBER						
										AREA CODE 7 0 3						
										8 9 4 - 5 1 5 1						
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS					CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS			
SUPPLEMENTAL REPORT EXPECTED (14)										EXPECTED SUBMISSION DATE (15)			MONTH DAY YEAR			
YES (If yes, complete EXPECTED SUBMISSION DATE)										X NO						

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On June 13, 1985 at 1220 hours, the Motor Driven Fire Pump was removed from service as a result of a maintenance activity. The Motor Driven Fire Pump was returned to operable status on June 28, 1985 at 2022 hours. As a result of the Motor Driven Fire Pump out of service for greater than seven days, this event is reportable as a Special Report pursuant to Unit 1 Technical Specifications 3.7.14.1 and 6.9.2.1 and Unit 2 Technical Specifications 3.7.14.1 and 6.9.2.1.

The redundant pump in the Fire Suppression System, the Diesel Driven Fire Pump, was operable during this event. The Warehouse Number 5 Electric and Diesel Driven Pumps were available during this event as backup water sources to the Fire Suppression System.

8508C10088 85/711
PDR ADOCK 05000338
S PDR

Tea
44

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

U.S. NUCLEAR REGULATORY COMMISSION

APPROVED OMB NO. 3150-0104

EXPIRES 8/31/85

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
NORTH ANNA POWER STATION, UNIT 1	0 5 0 0 0 3 3 8	8 5	— 0 0 1	— 0 0	0 2	OF	0 2

TEXT (If more space is required, use additional NRC Form 366A's) (17)

On June 13, 1985 at 1220 hours with both Unit 1 and Unit 2 operating at 100% power, the Motor Driven Fire Pump (EIIS system identifier KF, component identifier P) was removed from service. The Motor Driven Fire Pump is located at the Circulating Water intake structure (EIIS system identifier NN) and takes suction from the Unit 1 "B" Circulating Water Pump (EIIS identifier KE, component identifier P) suction bay. The Motor Driven Fire Pump was removed from service in order to perform maintenance on the Unit 1 "B" Circulating Water Pump which required draining of the suction bay. The Motor Driven Fire Pump was returned to operable status on June 28, 1985 at 2022 HRS after maintenance was completed on the Unit 1 "B" Circulating Water Pump and operability tests were completed with acceptable results. As a result of the Motor Driven Fire Pump out of service for a time period of greater than seven days, this event is reportable as a Special Report pursuant to Unit 1 Technical Specifications 3.7.14.1 and 6.9.2.1 and Unit 2 Technical Specifications 3.7.14.1 and 6.9.2.1.

The redundant pump in the Fire Suppression System (EIIS system identifier KF), the Diesel Driven Fire Pump (EIIS system identifier KF, component identifier P) located at the Service Water Reservoir (EIIS system identifier BI, component identifier RVR), was operable during the time period the Motor Driven Fire Pump was out of service. The Warehouse Number 5 Electric and Diesel Driven Fire Pumps (EIIS component identifier P) were available as backup water sources to the Fire Suppression System during this time period.

NORTH ANNA POWER STATION
P.O. BOX 402
MINERAL, VIRGINIA 23117



July 11, 1985

U. S. Nuclear Regulatory Commission
Document Control Desk
016 Phillips Building
Washington, D.C. 20555

Serial No. N-85-017
NO/JJM: kbs
Docket No. 50-338
50-339

License No. NPF-4
NPF-7

Dear Sirs:

Virginia Power hereby submits the following Licensee Event Report
applicable to North Anna Units 1 and 2.

Report No. LER 85-001-00

This report has been reviewed by the Station Nuclear Safety and Operating
Committee and will be forwarded to Safety Evaluation and Control for their
review.

Very Truly Yours,

E. Wayne Harrell
Station Manager

Enclosures (3 copies)

cc: Dr. J. Nelson Grace, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 2900
Atlanta, Georgia 30323

IE22
11