

WISCONSIN PUBLIC SERVICE CORPORATION

P.O. Box 19002, Green Bay, WI 54307-9002

Public**Service**

September 13, 1985

Mr. W. D. Shafer, Chief
Emergency Preparedness and
Radiological Protection Branch
U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137


Gentlemen:

Docket 50-305
Operating License DPR-43
Kewaunee Nuclear Power Plant
Inspection Report 85-009

Reference: Letter from W. D. Shafer (NRC) to D. C. Hintz (WPSC) dated
August 16, 1985, transmitting Inspection Report 50-305/85-009

The attachment to this letter details our response to the Notice of Violation
identified in inspection report 50-305/85-009 (DRSS).

Very truly yours,



D. C. Hintz
Manager - Nuclear Power

DSN/js

Attach.

cc - Mr. S. A. Varga, US NRC
Mr. Robert Nelson, US NRC

8509300232 850913
PDR ADOCK 05000305
Q PDR

IE 35
delete RIII

SEP 16 1985

Attachment
Response to Notice of Violation
Inspection Report 85-009

Notice of Violation

As a result of the inspection conducted on July 29 through August 2, 1985, and in accordance with the General Policy and Procedures for NRC Enforcement Actions, (10 CFR Part 2, Appendix C), the following violation was identified:

10 CFR Part 50.54(t) states in part that, "the licensee shall provide for a review of its emergency preparedness program at least every 12 months... The review shall include an evaluation for adequacy of interfaces with state and local governments... The results of the review, along with recommendations for improvements, shall be documented...."

Contrary to the above, the licensee's only review of their emergency preparedness program conducted in the last 12 months failed to evaluate and document the adequacy of interfaces with state and local governments.

This is a Severity Level V violation (Supplement VIII).

WPSC Response

Engineering Control Directive (ECD) 14.1 entitled "Independent Technical Review" will be revised to ensure that the annual Technical Review of the Kewaunee Nuclear Power Plant (KNPP) emergency preparedness program will include an evaluation for adequacy of interfaces with state and local governments. The results of the review, along with any recommendations for improvement will be documented in the technical review report.

This directive will be revised prior to the 1985 KNPP emergency planning exercise scheduled for October 22, 1985.