



**Northeast
Utilities System**

Millstone Offices • Rope Ferry Rd., Waterford, CT

P.O. Box 128
Waterford, CT 06385-0128
(203) 447-1791

December 16, 1996

Docket No. 50-245
B16033

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

This letter forwards Licensee Event Report (LER) 96-054-01, documenting an event that occurred at Millstone Nuclear Power Station, Unit No. 1 on October 30, 1996. This LER is submitted as a Special Report, pursuant to the Millstone Unit No. 1 Technical Specifications.

This supplemental report documents the closure on Commitment No. B16005-1, "The cause of the intermittent failures will be determined and it is expected that the High Range Stack Noble Gas Monitor will be returned to service prior to November 30, 1996," and Commitment No. B16005-2, "Supplemental report will be submitted prior to December 15, 1996, with cause of the intermittent problems."

The following is Northeast Nuclear Energy Company's (NNECO's) commitment made within this letter. All other statements made within this letter are for information only.

B16033-1 NNECO commits to conduct training on instrument grounding and reduction of Electrical Magnetic Interference/Radio Frequency Interference contributors for all Millstone Unit No. 1 engineering personnel by July 1, 1997.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

P. D. Hinnenkamp
Director, Unit Operations

190022

Attachment: LER 96-054-01

cc: Dr. W. D. Travers, Director, Special Projects
H. J. Miller, Region I Administrator
S. Dembek, NRC Project Manager, Millstone Unit No. 1
T. A. Easlick, Senior Resident Inspector, Millstone Unit No. 1

9612200058 961216
PDR ADOCK 05000245
S PDR

11/1
2022