

yellow

JUL 9 1985

✓ Alabama Power Company
ATTN: Mr. R. P. McDonald
Senior Vice President-Nuclear Generation
P. O. Box 2641
Birmingham, AL 35291

Gentlemen:

SUBJECT: REPORT NOS. 50-348/85-26 AND 50-364/85-26

On June 18 thru June 21, 1985, NRC inspected activities authorized by NRC License Nos. NPF-2 and NPF-8 for your Farley facility. At the conclusion of the inspection, the findings were discussed with those members of your staff identified in the enclosed inspection report.

Areas examined during the inspection are identified in the report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observation of activities in progress.

Within the scope of the inspection, no violations or deviations were identified.

During the inspection, the Technical Specification requirements pertaining to visual inspection of snubbers were discussed in detail with the Farley Plant Manager, Mr. Woodward, and his staff. As a result of these discussions, Mr. Woodward committed to revise the snubber surveillance procedures to require tabulation of snubbers that are found to be visually inoperable between scheduled visual snubber inspections. After completion of a scheduled visual snubber inspection, the interval for performance of the next visual inspection will be based on the total number of inoperable snubbers discovered since the last completed visual snubber inspection, plus the number of inoperable snubbers found during the most recently completed scheduled inspection. Please inform us if your understanding of this item is different from that stated above and discussed in the enclosed inspection report.

Should you have any questions concerning this letter, please contact us.

Sincerely,

David M. Verrilli for

Roger D. Walker, Director
Division of Reactor Projects

Enclosure: (See page 2)

8508010453 850709
PDR ADGCK 05000348
G PDR

IEO/11

JUL 9 1985

Enclosure:

Inspection Report Nos. 50-348/85-26
and 50-364/85-26

cc w/encl:

- ✓ W. O. Whitt, Executive Vice President
- ✓ J. D. Woodard, Plant Manager
- ✓ W. G. Hairston, III, Manager, Nuclear Engineering
and Technical Support
- ✓ J. W. McGowan, Manager-Safety Audit
and Engineering Review
- ✓ H. O. Thrash, Manager, Nuclear Operations
and Administration
- ✓ W. G. Ware, Supervisor-Safety Audit
and Engineering Review

bcc w/encl:

- Document Control Desk
- State of Alabama
- ✓ NRC Resident Inspector
- ✓ E. Reeves, Project Manager, NRR

RII

JJLeman:es

7/3 /85

RII

FJape

7/8 /85

RII

ARHerdt

7/9 /85

RII

AGibson

7/9 /85

RII

DVerrelli

7/9/85