

OPERATING DATA REPORT

UNIT NAME Millstone Unit 1
 DATE 12/12/96
 COMPLETED BY G. Newburgh
 TELEPHONE (860) 444-5730

OPERATING STATUS

1. Docket Number 50-245
 2. Reporting Period October 1996
 3. Utility Contact G. Newburgh
 4. Licensed Thermal Power (MWt): 2011
 5. Nameplate Rating (Gross MWe): 662
 6. Design Electrical Rating (Net MWe): 660
 7. Maximum Dependable Capacity (Gross MWe): 670
 8. Maximum Dependable Capacity (Net MWe): 641
 9. If Changes Occur in Capacity Ratings (Items Number 4 Through 8) Since Last Report, Give Reasons:
 N/A

Notes:

*Corrected on 12/12/96 to reflect Forced Outage beginning 12/13/95 @ 0000 due to 10CFR50.54(f) letter

^m EDT to EST

10. Power Level To Which Restricted, If any (Net MWe): 0
 11. Reasons For Restrictions, If Any: NRC Category III Facility; NRC Confirmatory Order requiring implementation of an independent corrective action verification program; NRC Order requiring a third-party review of the employee concerns program at Millstone Station; design basis verification response pursuant to 10CFR50.54(f).

| | This Month | Yr.-To-Date | Cumulative |
|--|--|-------------|-------------|
| 12. Hours In Reporting Period | 745.0 ^m | 7320.0 | 226536.0 |
| 13. Number Of Hours Reactor Was Critical | 0.0 | 0.0 | 170529.9 |
| 14. Reactor Reserve Shutdown Hours | 0.0 | 0.0 | 3283.3 |
| 15. Hours Generator On-Line | 0.0 | 0.0 | 166560.7 |
| 16. Unit Reserve Shutdown Hours | 0.0 | 0.0 | 93.7 |
| 17. Gross Thermal Energy Generated (MWH) | 0.0 | 0.0 | 314372827.0 |
| 18. Gross Electrical Energy Generated (MWH) | 0.0 | 0.0 | 105938737.0 |
| 19. Net Electrical Energy Generated (MWH) | -1943.0 | -22056.0 | 101047895.0 |
| 20. Unit Service Factor | 0.0 | 0.0 | 73.5 |
| 21. Unit Availability Factor | 0.0 | 0.0 | 73.6 |
| 22. Unit Capacity Factor (Using MDC Net) | -0.4 | -0.5 | 68.2 |
| 23. Unit Capacity Factor (Using DER Net) | -0.4 | -0.5 | 67.6 |
| 24. Unit Forced Outage Rate | *100.0 | *100.0 | *15.1 |
| 25. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): | *Shutdown for 10CFR50.54F at time of this report | | |

26. If Unit Shutdown At End Of Report Period, Estimated Date of Startup: To be determined
 27. Units In Test Status (Prior to Commercial Operation):

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

| Forecast | Achieved |
|----------|----------|
| N/A | N/A |
| N/A | N/A |
| N/A | N/A |

9612200119 961216
 PDR ADOCK 05000245
 R PDR

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-245
 UNIT NAME Millstone Unit 1
 DATE 11/12/96
 COMPLETED BY G. Newburgh
 TELEPHONE (860)-444-5730

REPORT MONTH: October 1996

| No. | Date | Type ¹ | Duration (Hours) | Reason ² | Method of Shutting Down Reactor ³ | License Event Report # | System Code ⁴ | Component Code ⁵ | Cause & Corrective Action to Prevent Recurrence |
|--------|--------|-------------------|---------------------|---------------------|--|------------------------------|-----------------------------|--------------------------------|--|
| 95-10J | 951213 | F | 745 | D | 4 | N/A | N/A | N/A | NRC Category III facility; NRC Confirmatory Order requiring independent corrective action verification; NRC Order requiring third-party review of Millstone Station employee concerns program; design basis verification for response to NRC pursuant to 10CFR50.54(f). RFO activities continue. |

¹ F: Forced
S: Scheduled

² Reason
A - Equipment Failure (Explain)
B - Maintenance or Test
C - Refueling
D - Regulatory Restriction
E - Operator Training & License Examination
F - Administrative
G - Operational Error (Explain)
H - Other (Explain)

³ Method
1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Continued from Previous Month
5 - Power Reduction (Duration = 0)
6 - Other (Explain)

⁴ IEEE Standard 805-1984,
"Recommended Practices
for System Identification in
Nuclear Power Plants and
Related Facilities"

⁵ IEEE Standard 803A-1983,
"Recommended Practices
for Unique identification in
Power Plants and Related
Facilities - Component
Function Identifiers"