

3. Special Reports

Special reports shall be submitted as indicated in Table 6.9.1.

6.10 RECORD RETENTION

A. The following records shall be retained for at least five years:

1. Records of facility operation covering time interval at each power level.
2. Records of principal maintenance activities, inspections, repair and replacement of principal items of equipment related to nuclear safety.
3. Reportable Event Reports.
4. Records of surveillance activities, inspections and calibrations required by these Technical Specifications.
5. Records of reactor tests and experiments.
6. Records of changes made to Operating Procedures.
7. Records of radioactive shipments.
8. Records of sealed source leak tests and results.
9. Records of annual physical inventory of all source material of record.

B. The following records shall be retained for the duration of the Operating License:

1. Record and drawing changes reflecting facility design modifications made to systems and equipment described in the Final Safety Analysis Report.
2. Records of new and irradiated fuel inventory, fuel transfers and assembly burnup histories.
3. Records of facility radiation and contamination surveys.
4. Records of radiation exposure for all individuals entering radiation control areas.
5. Records of the service lives of all hydraulic and mechanical snubbers listed in PNPS procedures including the date at which the service life commences and associated installation and maintenance records.

8509300322 850924
PDR ADOCK 05000293
P PDR