

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)
Nine Mile Point Unit IDOCKET NUMBER (2)
0 5 0 0 0 2 2 0PAGE (3)
1 OF 0 2TITLE (4)
Automatic Actuation of Control Room Emergency Ventilation System

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)
0 6	2 1	8 5	8 5	0 1	3 0	0 7	2 2	8 5			0 5 0 0 0

OPERATING MODE (9)	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)										
POWER LEVEL (10) 1 0 0	20.402(b)			20.405(c)			50.73(a)(2)(iv)			73.71(b)	
	20.405(a)(1)(i)			50.36(c)(1)			50.73(a)(2)(v)			73.71(c)	
	20.405(a)(1)(ii)			50.36(c)(2)			50.73(a)(2)(vii)			<input checked="" type="checkbox"/> OTHER (Specify in Abstract below and in Text, NRC Form 366A)	
	20.405(a)(1)(iii)			50.73(a)(2)(i)			50.73(a)(2)(viii)(A)			Voluntary Report	
	20.405(a)(1)(iv)			50.73(a)(2)(ii)			50.73(a)(2)(viii)(B)				
20.405(a)(1)(v)			50.73(a)(2)(iii)			50.73(a)(2)(ix)					

LICENSEE CONTACT FOR THIS LER (12)

NAME
Robert Randall, Supervisor, Technical SupportTELEPHONE NUMBER
AREA CODE
3 1 5 3 4 9 - 2 4 4 5

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)									
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC

SUPPLEMENTAL REPORT EXPECTED (14)
☐ YES (If yes, complete EXPECTED SUBMISSION DATE) ☒ NOEXPECTED SUBMISSION DATE (15)
MONTH DAY YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single space typewritten lines) (16)

ABSTRACT

On three separate occasions a spurious upscale deflection of a Control Room Vent Monitor (IL) caused the automatic actuation of the Control Room Emergency Ventilation System (VI). An inspection and a recalibration have been performed on the monitors (IL) involved. This event does not constitute an LER per 10 CFR 50.73 but is being prepared and submitted as a voluntary LER because of its generic nature.

B508010539 B50722
PDR ADOCK 05000220
S PDRIE22
1/

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

U.S. NUCLEAR REGULATORY COMMISSION

APPROVED OMB NO. 3150-0104

EXPIRES: 3/31/88

FACILITY NAME (1): Nine Mile Point Unit I	DOCKET NUMBER (2): 0 5 0 0 0 2 2 0	LER NUMBER (6)			PAGE (3)	
		YEAR 8 5	SEQUENTIAL NUMBER 0 1 3	REVISION NUMBER 0 0	0 2 OF 0 2	

TEXT (If more space is required, use additional NRC Form 366A-1/17)

Text

On June 21, 1985 and again on June 25, 1985, during normal operation, a spurious upscale deflection of a Control Room Vent Monitor (IL) caused the automatic actuation of the Control Room Emergency Ventilation System (VI). Automatic actuation of the Ventilation System (VI) also occurred on May 23, 1985. After the third occurrence it was decided to prepare and submit a voluntary LER because of the generic nature of these events. It is not mandatory that an LER be submitted, per 10 CFR 50.73, because the Control Room Emergency Ventilation System (VI) is not considered an Engineered Safeguard according to the Final Safety Analysis Report (FSAR). It is believed that the upscale deflections in the Control Room Vent Monitors (IL) were caused by a higher than normal level of line noise.

Assessment of Safety Consequences

There were no potential safety consequences arising out of this event because:

- 1) The Control Room Emergency Ventilation System (VI) operated correctly.
- 2) No Engineered Safeguard became inoperable.

Corrective Action

The Control Room Vent Monitors (IL) that were involved in the automatic actuation of the Control Room Emergency Ventilation System (VI) were recalibrated and steps are being taken in conjunction with the manufacturer to reduce the level of line noise.

NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK

300 ERIE BOULEVARD, WEST
SYRACUSE, N. Y. 13202

July 22, 1985

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555


RE: Docket No. 50-220
Ler 85-13

Gentlemen:

This report does not constitute an LER per 10 CFR 50.73, but is being submitted due to its generic nature.

This report was completed in the format designated in NUREG-1022 dated September 1983.

Very truly yours,


CV Mangan
Vice President
Nuclear Engineering & Licensing

CVM/tg
cc: Dr. Thomas E. Murley
Regional Administrator

Attachment

IE22
11