

JUL 19 1985

Mr. William J. Cahill, Jr.
Senior Vice President
River Bend Utilities Company
P.O. Box 2951
Beaumont, Texas 77704
Attention Mr. J. E. Booker

Dear Mr. Cahill:

SUBJECT: FEMA FINDING ON OFFSITE RADIOLOGICAL EMERGENCY PLANS

The enclosed memorandum from Richard W. Krimm, FEMA, dated July 5, 1985, forwards FEMA's finding on offsite radiological emergency response plans for the River Bend Nuclear Generating Station. FEMA indicates that the inadequacies in the offsite plans previously identified in its third interim finding dated May 10, 1985, have been corrected. FEMA specifies that the offsite radiological emergency plans and preparedness are adequate to provide reasonable assurance that appropriate measures can be taken to protect the health and safety of the public in the event of an accident at River Bend Station.

Please contact NRC Project Manager Stephen Stern (X28349) for clarification or further discussion on this topic.

Sincerely,

Original signed by

Walter R. Butler, Chief
Licensing Branch No. 2
Division of Licensing

Enclosure: As stated

cc: w/enclosure
See next page

DISTRIBUTION

Docket File	NRC PDR	Local PDR	PRC System	NSIC	LB#2REading	EHylton
OELD, Dewey	ACRS(16)	JPartlow	BGrimes	EJordan	DMatthews, IE	
DPerrotti, IE						

LB#2/DL/PM	LB#2/DL/BC	LB#2/DL/LA
SStern:mk	WButler	EHylton
7/18/85	7/18/85	7/ /85

Docket No. 50-458

JUL 19 1985

Mr. William J. Cahill, Jr.
Senior Vice President
River Bend Utilities Company
P.O. Box 2951
Beaumont, Texas 77704
Attention Mr. J. E. Booker

Dear Mr. Cahill:

SUBJECT: FEMA FINDING ON OFFSITE RADIOLOGICAL EMERGENCY PLANS

The enclosed memorandum from Richard W. Krimm, FEMA, dated July 5, 1985, forwards FEMA's finding on offsite radiological emergency response plans for the River Bend Nuclear Generating Station. FEMA indicates that the inadequacies in the offsite plans previously identified in its third interim finding dated May 10, 1985, have been corrected. FEMA specifies that the offsite radiological emergency plans and preparedness are adequate to provide reasonable assurance that appropriate measures can be taken to protect the health and safety of the public in the event of an accident at River Bend Station.

Please contact NRC Project Manager Stephen Stern (X28349) for clarification or further discussion on this topic.

Sincerely,

Original signed by

Walter R. Butler, Chief
Licensing Branch No. 2
Division of Licensing

Enclosure: As stated

cc: w/enclosure
See next page

DISTRIBUTION

Docket File	NRC PDR	Local PDR	PRC System	NSIC	LB#2Reading	EHylton
OELD, Dewey	ACRS(16)	JPartlow	BGrimes	EJordan	DMatthews, IE	
DPenrotti, IE						

LB#2/DL/PM
SStern:mk
7/18/85

LB#2/DL/BC
WButler
7/18/85

LB#2/DL/LA
EHylton
7/ /85



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JUL 19 1985

Docket No. 50-458

Mr. William J. Cahill, Jr.
Senior Vice President
River Bend Utilities Company
P.O. Box 2951
Beaumont, Texas 77704
Attention Mr. J. E. Booker

Dear Mr. Cahill:

SUBJECT: FEMA FINDING ON OFFSITE RADIOLOGICAL EMERGENCY PLANS

The enclosed memorandum from Richard W. Krimm, FEMA, dated July 5, 1985, forwards FEMA's finding on offsite radiological emergency response plans for the River Bend Nuclear Generating Station. FEMA indicates that the inadequacies in the offsite plans previously identified in its third interim finding dated May 10, 1985, have been corrected. FEMA specifies that the offsite radiological emergency plans and preparedness are adequate to provide reasonable assurance that appropriate measures can be taken to protect the health and safety of the public in the event of an accident at River Bend Station.

Please contact NRC Project Manager Stephen Stern (X28349) for clarification or further discussion on this topic.

Sincerely,

A handwritten signature in cursive script, reading "Walter R. Butler".

Walter R. Butler, Chief
Licensing Branch No. 2
Division of Licensing

Enclosure: As stated

cc: w/enclosure
See next page

Mr. William J. Cahill, Jr.
Gulf States Utilities Company

River Bend Nuclear Plant

cc:

Troy B. Conner, Jr., Esq.
Conner and Wetterhahn
1747 Pennsylvania Avenue, NW
Washington, D.C. 20006

Ms. Linda B. Watkins/Mr. Steven Irving
Attorney at Law
355 Napoleon Street
Baton Rouge, Louisiana 70802

Mr. William J. Reed, Jr.
Director - Nuclear Licensing
Gulf States Utilities Company
P. O. Box 2951
Beaumont, Texas 77704

Mr. David Zaloudek
Nuclear Energy Division
Louisiana Department of
Environmental Quality
P. O. Box 14690
Baton Rouge, Louisiana 70898

Richard M. Troy, Jr., Esq.
Assistant Attorney General in Charge
State of Louisiana Department of Justice
234 Loyola Avenue
New Orleans, Louisiana 70112

Mr. J. David McNeill, III
William G. Davis, Esq.
Department of Justice
Attorney General's Office
7434 Perkins Road
Baton Rouge, Louisiana 70808

Resident Inspector
P. O. Box 1051
St. Francisville, Louisiana 70775

H. Anne Plettinger
3456 Villa Rose Drive
Baton Rouge, Louisiana 70806

Gretchen R. Rothschild
Louisianians for Safe Energy, Inc.
1659 Glenmore Avenue
Baton Rouge, Louisiana 70775

James W. Pierce, Jr., Esq.
P. O. Box 23571
Baton Rouge, Louisiana 70893

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Office of Executive Director
for Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011



Enclosure

Federal Emergency Management Agency

Washington, D.C. 20472

JUL 5 1985

MEMORANDUM FOR: Edward L. Jordan
Director
Division of Emergency Preparedness and
Engineering Response
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission

FROM: *Richard W. Krimm*
Richard W. Krimm
Assistant Associate Director
Office of Natural and Technological Hazards

SUBJECT: Final Finding on Offsite Radiological Emergency Response
Plans for the River Bend Nuclear Generating Station

Attached is the final finding on the adequacy of the Louisiana Peacetime Radiological Response Plan (Revision V) site-specific to the River Bend Nuclear Generating Station. This finding was prepared by the Region VI Office staff of the Federal Emergency Management Agency.

The remaining NUREG-0654/FEMA REP-1, Rev. 1 evaluative criteria needing correction have been corrected and determined to be adequate. This involved G.3.a., J.10.e., L.3., and P.10 for the State of Louisiana and P.10. for the Parishes.

Consequently, as stated in my memorandum of May 10, 1985, the offsite radiological emergency plans and preparedness are adequate to provide reasonable assurance that appropriate measures can be taken to protect the health and safety of the public in the event of an accident at the River Bend Nuclear Generating Station.

If you have additional questions, please contact Mr. Robert S. Wilkerson, Chief, Technological Hazards Branch, at 646-2861.

Attachment
as stated

~~8507100007~~
3pp.

Listed below are the NUREG-0654 elements which were addressed by the State of Louisiana dated June 11, 1985.

G.3.a. FEMA Evaluation Comment

No physical location was identified for the news media center.

Action taken by State of Louisiana

The Joint Information Center is located in the River Bend Station Training Center. This facility is at the junction of U.S. 61 and the access road to the River Bend site.

The location of the Joint Information Center will be included in the Public Information portion of the next revision to the plan (Chapter 5 of the state plan).

Present Status - Adequate.

J.10.e. FEMA Evaluation Comment

Plan does not contain outline of where KI is to be stored; distribution to be made by LNED.

Action taken by State of Louisiana

A copy of the State's policy regarding KI was submitted to Region VI for review. Two hundred adult doses of KI are available at each of the five local EOC's. Additional doses will be maintained at the EOF for distribution by the State as needed.

Present Status - Adequate.

L.3. FEMA Evaluation Comment

The hospital list does not include the type of facility, capacity, and any special radiological capabilities.

Action taken by the State of Louisiana

Three hospitals have been identified for the handling of off-site contaminated/injured individuals. The following information pertains to these facilities:

<u>Hospital</u>	<u>Capacity</u>	<u>Radiological Capability</u>
Our Lady of the Lake	597	yes
Baton Rouge General	300	yes
West Feliciana	23	yes

This information will be included in the next revision to the plan (Chapter 10 of the State Plan).

Present Status - Adequate.

P.10. FEMA Evaluation Comment

Nothing stated in Implementing Procedures about insuring that telephone numbers are updated at least quarterly.

Action by the State of Louisiana

A statement will be added to the introduction to the implementing procedures as follows: Information on individuals and phone numbers which are included in the implementing procedures will be verified on at least a quarterly basis. Also, this information is already included in State Plan, page 27 Section VIII.D.5.

Present Status - Adequate.