



50-341

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

December 19, 1996

Mr. Douglas R. Gipson
Senior Vice President
Nuclear Generation
Detroit Edison Company
6400 North Dixie Highway
Newport, Michigan 48166

SUBJECT: ACTIONS ASSOCIATED WITH AN AMENDMENT REQUEST FOR THE TECHNICAL
SPECIFICATIONS FOR THE ROD BLOCK MONITOR AT FERMIL 2

Dear Mr. Gipson:

On December 2, 1996, you submitted an amendment request for Fermi 2 Technical Specifications (TS) 3.1.4.3, Rod Block Monitor and 3.3.6, Control Rod Block Instrumentation. In your submittal you explained that the applicability statement in the TS needed to be changed to ensure that all fuel limits would be met during Cycle 6 for a rod withdrawal error at power. Therefore, your proposed amendment would revise the applicability statement to include the entire range of conditions for which the rod block monitor should be operable.

In the interim, you have established administrative controls intended to ensure that appropriate actions, based on the proposed revised applicability statement, will be taken by plant personnel if one or more channels of the rod block monitor become inoperable. The administrative controls consist of a TS clarification in conjunction with a statement in the Core Operating Limits Report (COLR) concerning the revised applicability. The TS clarification states that the [existing] TS requirements for the Rod Block Monitor shall be applicable whenever thermal power is greater than or equal to 30% of rated thermal power. In addition, licensed operators have received training concerning the revised applicability of the technical specification.

The administrative controls described in your submittal appear to direct appropriate action by the operators if one or more channels of the rod block monitor becomes inoperable in the operating region not currently included in the technical specifications. Given that the administrative controls are more conservative than the existing technical specifications, the staff does not object to the use of these controls pending the completion of our review of your amendment request. In the interim, the staff expects that you will maintain the administrative controls you have described in place.

NRC FILE CENTER COPY

230059

9612230266 961219
PDR ADOCK 05000341
P PDR


DFG
10

D. Gipson

- 2 -

If you have any questions concerning this issue, please contact me.

Sincerely,

A handwritten signature in cursive script, reading "Andrew J. Kugler".

Andrew J. Kugler, Project Manager
Project Directorate III-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-341

cc: See next page

Mr. Douglas R. Gipson
Detroit Edison Company

Fermi-2

cc:

John Flynn, Esquire
Senior Attorney
Detroit Edison Company
2000 Second Avenue
Detroit, Michigan 48226

Drinking Water and Radiological
Protection Division
Michigan Department of
Environmental Quality
3423 N. Martin Luther King Jr Blvd
P. O. Box 30630 CPH Mailroom
Lansing, Michigan 48909-8130

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
6450 W. Dixie Highway
Newport, Michigan 48166

Monroe County Emergency Management
Division
963 South Raisinville
Monroe, Michigan 48161

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4351

Peter W. Smith
Director, Nuclear Licensing
Detroit Edison Company
Fermi-2 - 270 TAC
6400 North Dixie Highway
Newport, Michigan 48166

D. Gipson

- 2 -

December 19, 1996

If you have any questions concerning this issue, please contact me.

Sincerely,

Original signed by

Andrew J. Kugler, Project Manager
Project Directorate III-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-341

cc: See next page

DISTRIBUTION:

Docket File
PUBLIC
OGC
ACRS
PD3-1 Reading File
MJordan, RIII
AVeigel, RIII
JRoe
EAdensam (EGA1)
LPhillips
MYoung, OGC

DOCUMENT NAME: G:\WPDOCS\FERMI\FE-RBM.LTR

*See Previous Concurrence

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PD31	C	LA:PD31*	C	BC:SRXB	N	OGC	D:PD31	C
NAME	AKugler		CJamerson		TCollins		MYoung	JHannon	
DATE	12/19/96		12/03/96		12/19/96		12/19/96	12/19/96	

OFFICIAL RECORD COPY

D. Gipson

- 2 -

If you have any questions concerning this issue, please contact me.

Sincerely,

Andrew J. Kugler, Project Manager
Project Directorate III-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-341

cc: See next page

DISTRIBUTION:

Docket File
PUBLIC
OGC
ACRS
PD3-1 Reading File
MJordan, RIII
AVegel, RIII
JRoe
EAdensam (EGA1)
LPhillips
MYoung, OGC

DOCUMENT NAME: G:\WPDOCS\FERMI\FE-RBM.LTR

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PD31	C	LA:PD31	C	BC:SRXB	OGC	D:PD31	C
NAME	AKugler <i>AK</i>		CJamerson <i>CJ</i>		TCollins <i>TC</i>		JHannon	
DATE	12/3/96		12/3/96		12/3/96	12/ /96	12/ /96	

OFFICIAL RECORD COPY