

DMB

JUL 29 1985

Docket No. 50-341

The Detroit Edison Company
ATTN: Wayne H. Jens
Vice President
Nuclear Operations
6400 North Dixie Highway
Newport, MI 48166

Gentlemen:

This refers to the routine safety inspection conducted by Messrs. P. M. Byron, M. E. Parker, D. C. Jones, and R. A. Paul of this office on June 1-30, 1985, of activities at Fermi 2 authorized by Facility Operating License No. NPF-33 and to the discussion of our findings with R. S. Lenart at the conclusion of the inspection.

The enclosed copy of our inspection report identifies areas examined during the inspection. Within these areas, the inspection consisted of a selective examination of procedures and representative records, observations, and interviews with personnel.

No violations with NRC requirements were identified during the course of this inspection.

Although no violations of NRC requirements were identified during this inspection, we do request that you respond to the unresolved item identified in the enclosed report. This item is related to your maintenance activities and specifically involves the failure to follow procedures during Reactor Water Cleanup pump "A" maintenance. We believe this issue is significant and warrants particular attention. Your response is requested within thirty days of receipt of this letter.

Additionally, we request that you respond to the unresolved item concerning the program developed to address the serviceability of safety-related valves. Your response on this issue is also requested within thirty days of receipt of this letter.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC's Public Document Room.

8508020002 850729
PDR ADOCK 05000341
Q PDR

LEO1

The Detroit Edison Company

2

JUL 29 1985

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

"Original Signed by E.G. Greenman"

Charles E. Norelius, Director
Division of Reactor Projects

Enclosure: Inspection Report
No. 50-341/85029(DRP)

cc w/enclosure:

L. P. Bregni, Licensing
Engineer

P. A. Marquardt, Corporate
Legal Department

DMB/Document Control Desk (RIDS)

Resident Inspector, RIII

Ronald Callen, Michigan

Public Service Commission

Harry H. Voigt, Esq.

Nuclear Facilities and

Environmental Monitoring
Section

RIII

for RBL
Wright/rr
07/24/85

RIII

Chrysotimos

RIII

Norelius 7/28