

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)
Washington Nuclear Plant - Unit 2

DOCKET NUMBER (2)

0 5 0 0 0 3 9 7 1 OF 0 2

TITLE (4)

Missing Reactor Building Thermolagging for Cable Tray Fire Protection

EVENT DATE (5)				LER NUMBER (6)		REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)	
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES	DOCKET NUMBER(S)
06	11	98	58	5	043	00	07	28		050000
										050000

OPERATING MODE (9)		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following) (11)									
POWER LEVEL (10)	01010	20.402(a)	20.408(a)	50.73(a)(2)(v)	73.71(b)						
		20.408(a)(1)(i)	50.38(a)(1)	50.73(a)(2)(vi)	73.71(c)						
		20.408(a)(1)(ii)	50.38(a)(2)	50.73(a)(2)(vii)	OTHER (Specify in Abstract below and in Text, NRC Form 366A)						
		20.408(a)(1)(iii)	50.73(a)(2)(i)	50.73(a)(2)(viii)(A)							
		20.408(a)(1)(iv)	50.73(a)(2)(ii)	50.73(a)(2)(viii)(B)							
	20.408(a)(1)(v)	50.73(a)(2)(iii)	50.73(a)(2)(ix)								

LICENSEE CONTACT FOR THIS LER (12)

NAME	TELEPHONE NUMBER
W. S. Davison, Compliance Engineer	501 931 77-1 25101

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13) Ext. 2726

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE)	NO	EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

During performance of a Technical Specification required 18 month Fire Barrier Surveillance, two cables, one conduit, and a connection box were discovered as missing thermolag fire protective coating. The design configuration per 10CFR50 Appendix "R", requires these areas to be protected, but during construction the thermolag coating was not installed.

Immediate corrective action was taken to place these items on hourly fire watch.

8508020061 850722
PDR ADOCK 05000397
S PDR

IE22
111

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMB NO. 3150-0104

EXPIRES: 8/31/88

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
Washington Nuclear Plant - Unit 2	0 5 0 0 0 3 9 1 7 8 1 5	—	0 4 1 3	—	0 1 0	0 1 2 OF 0 1 2

TEXT (If more space is required, use additional NRC Form 308A's) (17)

Plant Conditions

- a) Power Level - 0%
- b) Reactor Mode - 4 (Cold Shutdown)

Event

On 6/19/85, while performing a Technical Specification required eighteen month surveillance of Reactor Building Fire Rated Assemblies, two cables, one conduit, and one connection box were found with missing thermolag fire protective coating. These cable enclosure fire barriers are required by the WNP-2 Plant Design. These barriers were not installed during initial Plant construction and are required to meet 10CFR50 Appendix "R" criteria.

Immediate Corrective Action

- o These items were immediately placed on the hourly fire watch patrol.

Further Corrective Action

- o The 18 month surveillance inspection, covering 100% of the Plant fire barriers was completed and no additional Appendix "R" infractions were found.
- o A Maintenance Work Request (MWR) has been generated to correct the identified deficiencies per existing design requirements.

Safety Significance

If a fire had occurred in the Reactor Building, it is possible that dedicated safe shutdown equipment might have been rendered inoperable. No fire occurred and fire protection systems have been in continuous operation in these areas since fuel load. There was no threat to the safety of the Plant, its personnel or the public as a result of this event.

Similar Events

See LER 85-028

Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

Docket No. 50-397

July 22, 1985


Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: NUCLEAR PLANT NO. 2
LICENSEE EVENT REPORT NO. 85-043

Dear Sir:

Transmitted herewith is Licensee Event Report No. 85-043 for WNP-2 Plant. This report is submitted in response to the report requirements of 10CFR50.73 and discusses the item of reportability, corrective action taken, and action taken to preclude recurrence.

Very truly yours,


C.M. Powers (M/D 927M)
WNP-2 Plant Manager

CMP:1a

Enclosure:
Licensee Event Report No. 85-043

cc: Mr. John B. Martin, NRC - Region V
Mr. A. D. Toth, NRC - Site (901A)
Ms. Dottie Sherman, ANI
INPO Records Center - Atlanta, GA

IE22
11